# PARTS REFERENCE GUIDE

**FOR** 

## Recessed **Pump Stations**





### Your Helpful Parts Resource

For S&L Product Codes: 14,26, 29 (First Two Numbers of Station Serial Number)

> Smith & Loveless, Inc. www.smithandloveless.com





14040 Santa Fe Trail Lenexa, KS 66215-1234, USA

After Market **Parts Price Book** Section 4 Recessed WWMPS Parts 3/1/21 Page 1

#### After Market Parts Catalog

## Recessed Wet Well Mounted Pump Stations S&L Product codes: 14, 26, 29 (First Two Numbers of Station Serial Number)

### **ALPHABETICAL PARTS LISTING**

<b>PART</b>	NAME PAGI	
	ADAPTER RING, VACUUM DOME • • • • • • • • • • • • • • • • • • •	
	AIR PRESSURE GAUGES · · · · · · · · · · · · · · · · · · ·	
	ALARM, PUMP FAILURE • • • • • • • • • • • • • • • • • • •	
	ALARM LIGHT•••••••9, 11	
	ALARMS	
	ALTERNATOR RELAY····································	
	ALTERNATOR TIMER • • • • • • • • • • • • • • • • • • •	
	ALTERNATORS•••••••9	
	ANODE PACK • • • • • • • • • • • • • • • • • • •	
	BLOWER • • • • • • • • • • • • • • • • • • •	
	BREAKER MOUNTING STRAPS – "QUICKLAG C" TYPE•••••••21	
	BREAKERS • • • • • • • 18-22	
	CAPACITOR – RECTIFIER – RESISTOR• · · · · · · · · · · · · · · · · · · ·	
	CHECK VALVE DRAIN, FLOAT CHECK VALVE • • • • • • • • • • • • • • • • • • •	
	CHECK VALVES, FLOAT · · · · · · · · · · · · · · · · · · ·	
	CHECK VALVES, WAFER • • • • • • • • • • • • • • • • • • •	
	CHECK VALVES, WAFER SPARE PARTS ••••••••••••49,49	
	COMBO GAUGE – VACUUM/AIR PRESSURE • • • • • • • • • • • • • • • • • • •	
	COMPRESSION RING, VACUUM DOME (RETAINER RING) • • • • • • • • • • • • • • • • • • •	
	CONTACTORS · · · · · · · · · · · · · · · · · · ·	
	CORD CONNECTOR, FOR FLOAT SWITCH • • • • • • • • • • • • • • • • • • •	
	CR RELAYS • • • • • • • • • • • • • • • • • • •	
	DEHUMIDIFIER • • • • • • • • • • • • • • • • • • •	
	DELAY TIMER	
	DIODE/RECTIFIER	
	DOME, RETROFIT ADAPTER RING	
	DOME, VACUUM OR ELECTRODE	
	DOUBLE BALANCED (High Head) MECHANICAL SEALS•••••••29	
	DUAL PISTON VACUUM PUMP	
	ELECTRODE, ALUMINUM	
	ELECTRODE DOME	
	ELECTRODE DOME ASSEMBLIES • • • • • • • • • • • • • • • • • • •	
	FLECTRODE DOME CONVERSION KITS	

© 2006 -2021 Smith & Loveless, Inc.



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 2

<u>PART</u>	<u>rname</u> P	<u>AGE</u>
	ELECTRODE, HOLLOW • • • • • • • • • • • • • • • • • • •	
	ELECTRODE, SOLID	
	ELECTRODE PARTS38	
	ELECTRODE RELAY • • • • • • • • • • • • • • • • • • •	, 13, 37
	EMERGENCY KIT • • • • • • • • • • • • • • • • • • •	
	ER RELAY (ELECTRODE RELAY) • • • • • • • • • • • • • • • • • • •	, 13, 37
	EXPANSION CARD • • • • • • • • • • • • • • • • • • •	
	FERRULE CONNECTION FITTING••••••••••••••••••••••••••••••••••	
	FERRULE NUT & SLEEVE	
	FIBERGLASS HOOD/LID • • • • • • • • • • • • • • • • • • •	
	FILTERS, VAPOR · · · · · · · 48	
	FITTINGS FOR TUBING • • • • • • • • • • • • • • • • • • •	
	FLANGE GASKETS · · · · · · · · · · · · · · · · · · ·	
	FLOAT (DISPLACEMENT) SWITCHES • • • • • • • • • • • • • • • • • • •	, 24
	FLOAT CHECK VALVES • • • • • • • • • • • • • • • • • • •	
	FRONT HEADS • • • • • • • • • • • • • • • • • • •	-27
	GASKETS • • • • • • • • • • • • • • • • • • •	, 35
	GASKETS, RECTANGULAR · · · · · · · · · · · · · · · · · · ·	, 35
	GASKETS, VOLUTE • • • • • • • • • • • • • • • • • • •	
	GAUGES, AIR PRESSURE · · · · · · · · · · · · · · · · · · ·	
	GAUGE, WATER • • • • • • • • • • • • • • • • • • •	
	GFCI RECEPTACLES • • • • • 10	
	GLOBES, GLOBE GUARDS FOR ALARM LIGHTS- $\cdots$ 9,	11
	HEATER • • • • • • • • • • • • • • • • • • •	
	HEATER COILS (OVERLOAD COILS FOR STARTERS) • • • • • • • • • • • • • • • • • • •	
	H-O-A (HAND-OFF-AUTO) SWITCH • • • • • • • • • • • • • • • • • • •	
	HOLLOW ELECTRODES · · · · · · · · · · · · · · · · · · ·	
	HOOD • • • • • • • • • • • • • • • • • •	
	HOOD (FIBERGLASS) REPAIR KIT • • • • • • • • • • • • • • • • • • •	
	HORN • • • • • 9	
	HOW TO CHANGE A SINGLE MECHANICAL SEAL VIDEO • • • • • • • • • • • • • • • • • • •	
	IMPELLER BOLTS & WASHERS • • • • • • • • • • • • • • • • • • •	
	IMPELLERS • • • • • • • • • • • • • • • • • • •	-27
	INTRINSICALLY SAFE RELAY • • • • • • • • • • • • • • • • • • •	
	KEYSTOCK (MOTOR SHAFT KEY) • • • • • • • • • • • • • • • • • • •	
	LID • • • • • • • • • • • • • • • • • • •	
	LIGHTNING PROTECTION • • • • • • • • • • • • • • • • • • •	
	LIGHTS • • • • • • • • • • • • • • • • • • •	
	LIGHT FIXTURE, ALARM LIGHTS • • • • • • • • • • • • • • • • • • •	11
	LOUVER, AIR VENT FOR HOOD · · · · · · · · · · · · · · · · · ·	1, 34



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 3

ART NA	AME	<b>PAGE</b>
N	MECHANICAL SEALS, SINGLE • • • • • • • • • • • • • • • • • • •	•28
N	MECHANICAL SEAL VIDEO, HOW TO CHANGE • • • • • • • • • • • • • • • • • • •	•35
	MOTOR ADAPTERS · · · · · · · · · · · · · · · · · · ·	
N	MOTORS	•20
N	MOTOR SHAFT KEY (KEYSTOCK) • • • • • • • • • • • • • • • • • • •	•34
1	NAME PLATE FOR SERIAL NUMBERS • • • • • • • • • • • • • • • • • • •	•34
(	D&M'S • • • • • • • • • • • • • • • • • • •	•34
(	OVERLOAD COILS	•17
	PAINT · · · · · · · · · · · · · · · · · · ·	
	PHASE MONITOR RELAYS · · · · · · · · · · · · · · · · · · ·	
	PLUG VALVES · · · · · · · · · · · · · · · · · · ·	
	PLUG VALVE HANDLE/WRENCH • • • • • • • • • • • • • • • • • • •	
	POWER SUPPLY · · · · · · · · · · · · · · · · · · ·	
	PRESSURE SWITCH, STATION FLOODING ALARM • • • • • • • • • • • • • • • • • • •	
	PRESSURE TRANSDUCERS/SENSORS, SUBMERSIBLE • • • • • • • • • • • • • • • • • • •	
	PROTECTION, LIGHTNING • • • • • • • • • • • • • • • • • • •	
	PROTRONIX® I · · · · · · · · · · · · · · · · · ·	
	PROTRONIX® II · · · · · · · · · · · · · · · · · ·	
	PUMP ALTERNATORS • • • • • • • • • • • • • • • • • • •	
	PUMP FAILURE ALARM • • • • • • • • • • • • • • • • • • •	
	PUMP PARTS & STANDS	
	QUICK DISCONNECT FITTINGS	
	RECTIFIER/DIODE – RESISTOR – CAPACITOR • • • • • • • • • • • • • • • • • • •	
	REDUCED MAINTENANCE VACUUM PRIMING SYSTEM KITS	
	RELAYS	•
	RESISTOR – CAPACITOR – RECTIFIER/DIODE • • • • • • • • • • • • • • • • • • •	
	RUNNING TIME HOUR METER (RUNNING TIME METER)	
	SCREEN SUN BLOCKER ( <b>SHADE AIDE™</b> ) • • • • • • • • • • • • • • • • • • •	
	SEALS, SINGLE MECHANICAL••••••••••••••••••••••••••••••••••••	
	SHADE AIDE™	
	SINGLE PISTON VACUUM PUMP································	
	SINGLE MECHANICAL SEAL · · · · · · · · · · · · · · · · · · ·	
	SLEEVE WRENCH, 3-WAY SOLENOID VALVE • • • • • • • • • • • • • • • • • • •	
	SLINGER RINGS (FOR MOTOR SHAFT) • • • • • • • • • • • • • • • • • • •	
	SOLENOID VALVES · · · · · · · · · · · · · · · · · · ·	
	SOLID ELECTRODE····································	•
	SONIC START® KITS · · · · · · · · · · · · · · · · · · ·	
	SONIC START® OPERATING MODULE	



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 4

#### PART NAME PAGE

SONIC START® VACUUM DOME ASSEMBLY••••••••••••••••••••••••••••••••••••
SPRING LOADED WAFER CHECK VALVE••••••••••43
STATION FLOODING PRESSURE SWITCH ALARM • • • • • • • • • • • • • • • • • • •
STARTERS • • • • • • • • • • • • • • • • • • •
SUMP PUMP • • • • • • • • • • • • • • • • • • •
SURGE CAPACITOR · · · · · · · · · · · · · · · · · · ·
SWITCHES • • • • • • • • • • • • • • • • • • •
SWITCHES, FLOAT• • • • 10, 24
TEMPERATURE CONTROL (THERMODISC) • • • • • • • • • • • • • • • • • • •
THREE-WAY SOLENOID VALVE • • • • • • • • • • • • • • • • • • •
TIME METER, RUNNING • • • • • • • • • • • • • • • • • • •
TIMER • • • • • • • • • • • • • • • • • • •
TOUCH-UP PAINT- · · · · · · · · · · · · · · · · · · ·
TRAINING VIDEO, HOW TO CHANGE A SINGLE MECH. SEAL•••••••35
TRANSFORMER • • • • • • • • • • • • • • • • • • •
TUBING, VACUUM • • • • • • 43
TWO-WAY SOLENOID VALVE • • • • • • • • • • • • • • • • • • •
VACUUM-AIR PRESSURE GAUGES · · · · · · · · · · · · · · · · · · ·
VACUUM DOMES••••••••••••••44
VACUUM PRIMING SYSTEM REDUCED MAINTENANCE KITS • • • • • • • • • • • • • • • • • • •
VACUUM PUMP RELAY – CR RELAY • • • • • • • • • • • • • • • • • • •
VACUUM PUMPS • • • • • • • 44-47
VACUUM TUBING · · · · · · · · · · · · · · · · · · ·
VACUUM TUBING FITTINGS · · · · · · · · · · · · · · · · · · ·
VALVES, FLOAT CHECK ••••••••••••••••••••••••••••••••••••
VALVES, PLUG • • • • • • • • • • • • • • • • • • •
VALVE SLEEVE WRENCH • • • • • • • • • • • • • • • • • • •
VALVES, SOLENOID • • • • • • • • • • • • • • • • • • •
VALVES, WAFER CHECK VALVE ••••••••••••••••••••••••••••••••••••
VAPOR FILTERS • • • • • • • 48
VENTILATION BLOWER••••••••••••••••••••••••••••••••••••
VERSAPOX®, PAINT · · · · · · · · · · · · · · · · · · ·
VIDEOS – DVD & VHS • • • • • 35
VOLTAGE SUPPRESSOR • • • • • • • • • • • • • • • • • • •
VOLUTE GASKETS · · · · · · · · · · · · · · · · · · ·
VOLUTES • • • • • • • • • • • • • • • • • • •
WAFER CHECK VALVES · · · · · · · · · · · · · · · · · · ·
WAFER CHECK VALVE SPARE PARTS••••••50,51
WATER GAUGE





14040 Santa Fe Trail Lenexa, KS 66215-1234, USA

After Market **Parts Price Book** Section 4 Recessed WWMPS Parts 3/1/21 Page 5

#### After Market Parts Catalog

## Recessed Wet Well Mounted Pump Stations S&L Product codes: 14, 26, 29 (First Two Numbers of Station Serial Number)

<u>PAR I</u>	<u> </u>	<u>PAGE</u>
ELEC	CTRICAL COMPONENTS	
	ALARMS	• • •9
	ALTERNATORS, PUMP•••••••••••••••••••••••••••••••••••	•••9
	CR RELAYS (VACUUM PUMP RELAY)••••••••••••••••••••••••••••••••••••	• • ••10, 13
	ER RELAYS (ELECTRODE RELAY)••••••••••••••	• • ••10, 13
	FLOAT (DISPLACEMENT) SWITCHES	• • ••10
	FLOAT SWITCHES, CORD CONNECTOR • • • • • • • • • • • • • • • • • • •	• • ••10
	GFCI RECEPTACLES • • • • • • • • • • • • • • • • • • •	•••10
	HEATER • • • • • • • • • • • • • • • • • • •	• • •11
	LIGHTNING PROTECTION · · · · · · · · · · · · · · · · · · ·	• • •11
	LIGHTS·····	• • •11
	PHASE MONITOR RELAYS••••••••••••••••••••••••••••••••••••	•••11
	POWER SUPPLY · · · · · · · · · · · · · · · · · · ·	
	PRESSURE TRANSDUCERS/SENSORS, SUBMERSIBLE • • • • • • • • • • • • • • • • • • •	
	PROTECTION, LIGHTNING •••••••••••••••••••••••••••••••••••	
	PROTRONIX® I · · · · · · · · · · · · · · · · · ·	
	PROTRONIX® II · · · · · · · · · · · · · · · · · ·	
	EXPANSION CARD	
	PUMP FAILURE ALARM • • • • • • • • • • • • • • • • • • •	
	RECTIFIER(DIODE) – RESISTOR – CAPACITOR · · · · · · · · · · · · · · · · · · ·	
	RELAYS • • • • • • • • • • • • • • • • • • •	
	RUNNING TIME HOUR METER • • • • • • • • • • • • • • • • • • •	
	SOLENOID VALVES · · · · · · · · · · · · · · · · · · ·	
	STARTERS - NEMA••••••••••••••••••••••••••••••••••••	
	STARTERS - IEC- · · · · · · · · · · · · · · · · · · ·	
	OVERLOAD COILS••••••••••••••••••••••••••••••••••••	
	BREAKERS, THREE PHASE MOTOR CIRCUIT BREAKERS	
	BREAKERS, SINGLE PHASE MOTOR CIRCUIT BREAKERS	
	BREAKERS – "QUICKLAG C" TYPE •••••••••••	
	BREAKER MOUNTING STRAPS – "QUICKLAG C" TYPE	
	BREAKERS – THERMAL MAGNETIC "EHD" TYPE • • • • • • • • • • • • • • • • • • •	
	BREAKERS- MCP MOTOR CIRCUIT PROTECTOR · · · · · · · · · · · · · · · · · · ·	
	MOTORS	
	TEMPERATURE CONTROL (THERMODISC)	24



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 6

<u>PART</u>	NAME	<u>PAGE</u>
	TIMER • • • • • • • • • • • • • • • • • • •	24
	TRANSFORMER · · · · · · · · · · · · · · · · · · ·	24
	SWITCHES	24
	VOLTAGE SUPPRESSOR · · · · · · · · · · · · · · · · · · ·	24
MECH	IANICAL, PIPING, & PARTS	
	·	
	PUMP PARTS	
	Includes: shaft diameter, impeller, maximum diameter, Suction Side - Diar head, pump stand, volute, gaskets, motor adapter, impeller bolt, impe	•
	4B2B*1, TURBO 4B2C, 4B2D, 4B3B, 4C2B, 4C2D • • • • • • • • • • • • • • • • • • •	25
	4C3B, 4D3B, 4D4B, 6B3B, 6B3B (SERIES), 6C3B • • • • • • • • • • • • • • • • • • •	26
	6C3B (SERIES), 6D3B, 6D3B (SERIES), 8C4D, 8D4D • • • • • • • • • • • • • • • • • •	27
	MECHANICAL SEALS	
	B-SHAFT (17/8") (Seals & Spare Parts) · · · · · · · · · · · · · · · · · · ·	28
	C-SHAFT (21/8") (Seals & Spare Parts) • • • • • • • • • • • • • • • • • • •	
	D-SHAFT (3") (Seals & Spare Parts) · · · · · · · · · · · · · · · · · · ·	
	DOUBLE BALANCED MECHANICAL SEALS	
	VOLUTE GASKETS	30
PUMP	IMPELLERS	
	IMPELLERS	30
	X-PELLER® IMPELLERS · · · · · · · · · · · · · · · · · · ·	
	X-I LLLLIN IVII LLLLINGUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUU	00
OTHE	R PARTS	
	ANODE PACK••••••••••••••••••••••••••••••••••••	31
	BLOWER	31
	DEHUMIDIFIER	31
	EMERGENCY KIT • • • • • • • • • • • • • • • • • • •	31
	GASKETS · · · · · · · · · · · · · · · · · · ·	32
	GASKETS, VOLUTE····································	32
	GAUGES, AIR PRESSURE•••••••••••••••••••••••••••••••••	32
	GAUGES, COMBO – VACUUM/AIR PRESSURE • • • • • • • • • • • • • • • • • • •	33
	GAUGES, WATER••••••••••••••••••••••••••••••••••••	33
	HOOD•••••••••	33



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 7

PART NAME		PAGE
HOOD (FIBERG	GLASS) REPAIR KIT • • • • • • • • • • • • • • • • • • •	• • • • • • 33
	OTOR SHAFT KEY)••••••	
	NT IN HOOD	
OTHER PARTS (CO	ONTINUED)	
-	FOR S&L SERIAL NUMBERS · · · · · · · · · · · · · · · · · · ·	• • • • 34
O&M'S • • • • •		• • • •34
PAINT (VERSAI	POX® & TOUCH-UP KITS) • • • • • • • • • • • • • • • • • • •	• • • ••34
RECTANGULAR	R GASKETS · · · · · · · · · · · · · · · · · · ·	• • • •35
SAFETY EQUIP	PMENT·····	• • • •35
SHADE AIDE™	' (HMI SCREEN SUN BLOCKER)• · · · · · · · · · · · · · · · · · · ·	••••35
	GS (for Motor Shaft) • • • • • • • • • • • • • • • • • • •	
SUMP PUMPS•		• • • •35
VIDEOS – TRAI	INING ON SINGLE MECHANICAL SEAL·······	• • • • •35
VACUUM PRIMIN	G SYSTEM	
		0.0
	•••••	
	OOMES	
	OOME ASSEMBLIES • • • • • • • • • • • • • • • • • • •	
	RELAYES – ER1 & ER2•••••••	
	«ELAYES – ERΙ α ERΖ••••••••••••••••••••••••••••••••••••	
	– NEW STYLE SOLID S.S. ELECTRODE • • • • • • • • • • • • • • • • • • •	
	- OLD STYLE	
	- OLDER STYLE - HOLLOW S.S. ELECTRODE • • • • • • •	
	VALVES · · · · · · · · · · · · · · · · · · ·	
	VALVES – OLDER STYLE • • • • • • • • • • • • • • • • • • •	
	INTENANCE VACUUM PRIMING SYSTEM KITS • • • • • •	
SOLENOID VAL	LVES	• • • • 42
SONIC START®	®KITS • • • • • • • • • • • • • • • • • • •	•••••42
	® REPLACEMENT KITS • • • • • • • • • • • • • • • • • • •	
SONIC START®	®VACUUM DOME ASSEMBLY • • • • • • • • • • • • • • • • • • •	• • • • 43
SONIC START®	VACUUM DOME INDIVIDUAL PARTS · · · · · · · · · · · · · · · · · · ·	• • • •44
VACUUM PUMF	P – HEAVY DUTY – SINGLE PISTON & PARTS······	• • • •44
	P – STANDARD – SINGLE PISTON PARTS · · · · · · · · · · · · · · · · · · ·	
VACUUM PUMF	P – HEAVY DUTY – DUAL PISTON & PARTS · · · · · · · · · · ·	••••46
VACUUM PUMF	P – OLD 8L40A - DUAL PISTON PARTS ONLY•••••••	• • • • •47





14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 8

### **VACUUM PRIMING SYSTEM**

	VACUUM TUBING · · · · · · · · · · · · · · · · · · ·
	VACUUM TUBING FITTINGS•••••••48
	VAPOR FILTER · · · · · · · · · · · · · · · · · · ·
VALVE	S
	PLUG VALVES • • • • • • 49
	PLUG VALVE HANDLE / WRENCH · · · · · · · · · · · · · · · · · · ·
	WAFER CHECK VALVES, SPRING LOADED • • • • • • • • • • • • • • • • • •
	WAFER CHECK VALVES, 4", SPARE PARTS · · · · · · · · · · · · · · · · · · ·
	WAFER CHECK VALVES, 6", SPARE PARTS • • • • • • • • • • • • • • • • • • •
PARTS	LIST
	SUGGESTED SPARE PARTS LIST······52
	GENERAL LIST OF OTHER POSSIBLE SPARE PARTS53 54



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 9

#### **ELECTRICAL COMPONENTS**

ALARMS	
PART DESCRIPTION	PART#
Station Flooding Pressure Switch	4L178
Telephone Line 8 Pin Relay for Remote Alarm Panel	4L191
Socket Base, 8 Pin, for 4L191 relay	5L49B
Horn, 120 VAC, 60 cycle	4L73A
Horn, 12 VDC.	4L73B
Horn, Weatherproof Box	4L73D
RED ALARM LIGHT ASSEMBLY:	
Light, Red 12 VDC	28B580A
Lamp, 12 VDC, 50 W for 28B580A Light	4L120
Light, Red 120 VAC	28B580B
Lamp, 120 VAC, 50 W for 28B580B Light	4L95A
Light Fixture Body for Alarm Light	5L76 *
Light Fixture Adapter for Alarm Light	5L77 *
Red Globe for 5L77 for Alarm Light	5L78B *
Globe Guard for 5L77 for Alarm Light	5L79 *
Trickle Charger (CURRENT) Can be used in place of 4L222	4L222C**
Trickle Charger (OLD STYLE)	4L222

<sup>\* &</sup>lt;u>PARTS ORDERING NOTE:</u> Must identify as either Appleton or Killark \*\*Consult the factory.

ALTERNATORS, PUMP	
PART DESCRIPTION	PART#
Alternator for older stations – plug-in with 12 pin rectangular base (replaces 4L187) (Can also be modified to PN 4L187B. Requires wiring modifications.)	4L187A
Socket Base, 12 pin rectangular, for Alternator 4L187A	5L161
Alternator (orange) for newer stations – plug-in with 11 pin round base	4L187B
Socket Base, 11 pin round, for Alternator 4L187B	5L49C
Alternator/Timer for old stations, 2 Switches, Wire-in 16 Hour (8 on/off) (Replaces Zenith 4L282A)	4L343 *
Alternator/Timer for new stations, 1 Switch, Wire-in 16 Hour (8 on/off)	4L365A
Relay, Alternator	4L105A
*	

<sup>\* &</sup>lt;u>PARTS ORDERING NOTE:</u> Customer will require wiring installation instructions if this replaces a 4L282A

#### **CONTACTORS**

Not descriptive enough. Ask customer if they mean contact terminal block, Auxiliary Relay, Starter, etc.



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 10

### **ELECTRICAL COMPONENTS (CONTINUED)**

CR RELAYS (\	VACUUM PUMF	RELAY)
--------------	-------------	--------

PART DESCRIPTION	PART #
Relay, for Vacuum Pump (1CR, 2CR)	4L107F
Relay, for Vacuum Pump (1CR, 2CR) "Series Stations"	4L424A

#### **ER RELAYS (ELECTRODE RELAY)**

PART DESCRIPTION	PART#
Relay, for Electrode current style - (1ER, 2ER)	4L408Q
(requires modification if replacing 4L29 or 4L408)	4L400Q
Relay, for Electrode – (1ER, 2ER) Older Style	4L29*
(determine which part is needed)	4L29
Socket Base, 8 pin for 4L29 Relay	5L49B
SONIC START® Operating Module	4L264

<sup>\*</sup> If customer switches to 4L408Q SONIC START® STREAMLINE™ or WaveStart® from the 4L29 Electrode Relay, the Rectifier/ Diode, Resistor & Capacitor are no longer required in the control panel.

FLOAT (DISPLACEMENT) SWITCHES	
PART DESCRIPTION	

PART DESCRIPTION	PART #
Float Switch (Normally Open <b>Blue</b> ), 30 ft. cord	4L291A
(P/N 87A80 Obsolete-Replaced by 4L291A)	4L29TA
Float Switch (Normally Closed Red), 30 ft. cord	4L291B
Float Switch (Normally Open Blue), 45 ft. cord	4L291C
Non Mercury Float Switch	4L291F

### CORD CONNECTOR, FOR FLOAT SWITCHES

PART DESCRIPTION	PART #
Cord Connector, Float Switch Adjustment	5L57C

GROUND FAULT CIRCUIT INTERRUPTER (GFCI) RECEPTACLES	
PART DESCRIPTION	PART #
GFCI Receptacle, 15 Amp, Color: Ivory	5L269C
GFCI Receptacle, 20 Amp, Color: Ivory	5L269D
GFCI Receptacle, 20 Amp, Color: Black	5L269E



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 11

### **ELECTRICAL COMPONENTS** (CONTINUED)

,		
HEATER		
PART DESCRIPTION	PART #	
Heater, Strip/Panel Mount 120 Volt 500 Watt (Replaces 4L276)	OBSOLETE	
(OBSOLETE P/N 4L364 replaced with P/N 4L364A)		
Heater, Strip/Panel Mount with Thermostat – UL Listed 120 Volt 500 Watt	4L364A	
Heater, Auxiliary, with Fan, 120 Volt 1320/1650 Watt	4L84	
Fan Motor for 4L84 Heater	OBSOLETE	
Thermostat Switch for 4L84 Heater	OBSOLETE	
LIGHTNING PROTECTION		
PART DESCRIPTION	PART#	
Surge Capacitor	4L368	
Lightning Arrestor	4L369	

LIGHTS	
PART DESCRIPTION	PART #
Light, Red Neon, Indicator Light for Panel (Replaces 5L243)	4L293A
RED ALARM LIGHT ASSEMBLY:	
Light, Red 12 VDC	28B580A
Lamp, 12 VDC, 50 W for 28B580A Light	4L120
Light, Red 120 VAC	28B580B
Lamp, 120 VAC, 50 W for 28B580B Light	4L95A
Light Fixture, Fluorescent 48"L x 5"W x 3-5/8"H (Order Bulb Separately)	4L136
Lamp, Fluorescent 120 VAC 40 W for 4L136 Light Fixture (2 required)	4L134A
Light Fixture UL Listed, Fluorescent 36"L x 4-5/8"W x 4-5/8"H Order Bulb Separately)	5L276A
Lamp, 30 Watt Fluorescent for 5L276A Fixture (2 required)	5L276B
Light Fixture Body for Alarm Light	5L76 *
Light Fixture Adapter for Alarm Light	5L77 *
Red Globe for 5L77 for Alarm Light	5L78B *
Globe Guard for 5L77 for Alarm Light	5L79 *
	-

<sup>\*</sup> PARTS ORDERING NOTE: Must identify as either Appleton or Killark

PHASE MONITOR RELAYS	
PART DESCRIPTION	PART #
Phase Monitor, Voltage: 190 to 270	4L336A
Phase Monitor, Voltage: 430 to 480	4L336B



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA **After Market Parts Price Book** Section 4 Recessed WWMPS Parts 3/1/21 Page 12

POWER SUPPLY – 24 VOLT	
Powers all 24 volt panel components	
PART DESCRIPTION	PART #
Power Supply, 24 VDC (2.3 Amp rating)	4L452C
PRESSURE TRANSDUCERS/SENSORS, SUBMERSIBLE (Submersible Pressure Transducer hangs down from the pump station and into the wet well, in add switches used for back-up. Both are used for wet well level sensing.)	dition to the float
PART DESCRIPTION	PART#
0-15 PSI, Submersible Pressure Transducer – 25' Cord (old style)	See
0-15 PSI, Submersible Pressure Transducer – 25' Cord (old style) (Old PN: 4L563B-Now 4L563J + reprogrammed E-PROM through Retrofit)	See Retrofit
(Old PN: 4L563B-Now 4L563J + reprogrammed E-PROM through Retrofit) 0-7.5 PSI, Submersible Pressure Transducer – 30' Cord (Replaces 4L563A) (CURRENT STYLE) (Replaces 4L563C).	Retrofit
(Old PN: 4L563B-Now 4L563J + reprogrammed E-PROM through Retrofit)  0-7.5 PSI, Submersible Pressure Transducer – 30' Cord (Replaces 4L563A) (CURRENT STYLE) (Replaces 4L563C).  PROTRONIX CONTROLLER	Retrofit 4L563J
(Old PN: 4L563B-Now 4L563J + reprogrammed E-PROM through Retrofit) 0-7.5 PSI, Submersible Pressure Transducer – 30' Cord (Replaces 4L563A) (CURRENT STYLE) (Replaces 4L563C).	Retrofit



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 13

#### **ELECTRICAL COMPONENTS (CONTINUED)**

### RECTIFIER [DIODE] - RESISTOR - CAPACITOR

(only used with 4L29\* electrode relay)

PART DESCRIPTION	PART #
Rectifier Replacement Kit (includes rectifier [diode], capacitor, & resistor)	80A145
Rectifier [Diode], 2½ Amp max.	4L119A
Resistor, 5K Ohm, 31/4 Watt	4L278A
Capacitor, 20 MF rating	4L277A

<sup>\*</sup> If customer switches to 4L408H, SONIC START® STREAMLINE™, or WaveStart® from the 4L29 Electrode Relay, the Rectifier/ Diode, Resistor & Capacitor are no longer required in the control panel.

RELAYS	1
PART DESCRIPTION	PART#
Relay, for Alternator	4L105A
	·
Relay, for Vacuum Pump (1CR, 2CR)	4L107F
Relay, for Vacuum Pump (1CR, 2CR) "Series Stations"	4L424A
Relay, Intrinsically Safe Relay (Replaces 4L279A)	4L374
Relay, for Electrode (1ER, 2ER) Current Style	4L408Q
(requires modification if replacing 4L29 or 4L408)	
Relay, for Electrode – (1ER, 2ER) Older Style	4L29*
(determine which part is needed)	
Socket Base, 8 pin for 4L29 Relay	5L49B
SONIC START® Operating Module	4L264
WaveStart® Operating Module	4L264E

<sup>\*</sup> If customer switches to 4L408Q, or SONIC START® STREAMLINE™, or WaveStart® from the 4L29 Electrode Relay, the Rectifier/Diode, Resistor & Capacitor are no longer required in the control panel.



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 14

### **ELECTRICAL COMPONENTS (CONTINUED)**

RUNNING TIME METER	
PART DESCRIPTION	PART#
Running Time Meter	4L198A
SOLENOID VALVES (IN PORT GOES TO DOME, OUT PORT GO	ES TO VACUUM PUMP)
PART DESCRIPTION	PART #
SONIC START® STREAMLINE™ and WaveStart® Vacuum Dome for Pump Stations (NEWEST Solenoid Dome Arrangement	87B728
2-Way Solenoid Valve (5/16" orifice) (Newest Solenoid – Upgrade from 1L406A & 1L406E Style)	1L545A remote mounted using standard DIN connection & used on SONIC START® STREAMLINE™ and WaveStart® Vacuum Dome
DIN Connector for 1L545A with 8' cord (OLD P/N: 1L545A-1) (Required for initial installation of 1L545A)	87A481-STK
Solenoid Clip (top piece removed when solenoid opened, clip holds unit in place)	1L545A-3
2-Way Solenoid Valve (5/16" orifice) (Newest Solenoid – Upgrade from 1L406A & 1L406E Style)	1L545B conduit connection mounted through panel & backpan
Solenoid Clip (top piece removed when solenoid opened, clip holds unit in place)	1L545A-3
Reduced Maintenance Vacuum Priming System Retrofit Kit	OBSOLETE
2-Way Solenoid Valve (5/16" orifice) (Old PN: H87A343A) (Newest – Upgrade from 1L406A & 1L406E Style)	OBSOLETE
3-Way Solenoid Valve (3/32" orifice) (Replaced Old Style 1L299A, 1L349A & 1L406A) Current S&L standard solenoid valve is the PN 1L545A remote mounted needs DIN connector PN 1L545A-1 or PN1L545B that mounts through control panel and backpan. Conduit Connector, Ref: 87B16.)	1L406E
Conduit Nut for 3-Way Solenoid Valve (required when ordering 1L406E first time)	5L13A
Valve Sleeve Wrench for 1L406A	1L406W
Valve Sleeve Wrench for 1L406E	1L406EW



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 15

#### ELECTRICAL COMPONENTS (CONTINUED)

#### **NEMA RATED STARTERS - 4L421**

Motor Horsepower	208 Volts	230 Volts	460 Volts
	Part Numbers	Parts Numbers	Parts Numbers
<sup>3</sup> / <sub>4</sub> & 1	4L421A	4L421A	4L421A
1½	4L421A	4L421A	4L421A
2	4L421A	4L421A	4L421A
3	4L421A	4L421A	4L421A
5	4L421B	4L421B	4L421B
7½	4L421B	4L421B	4L421B
10	4L421C	4L421C	4L421B
15	4L421D	4L421C	4L421C
20	4L421D	4L421D	4L421C
25	4L421D	4L421D	4L421C
30	4L421E	4L421D	4L421D
40	4L421E	4L421E	4L421D
50	4L421F	4L421E	4L421D
60	4L421F	4L421F	4L421E
75	4L421F	4L421F	4L421E
100	Special Order	4L421F	4L421E

**PARTS ORDERING NOTE:** If the customer is replacing older starters with new starters (new part numbers listed above), they will also need to purchase new overload coils and auxiliary contacts.

**CALL FACTORY FOR DIMENSIONS** 



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 16

### **ELECTRICAL COMPONENTS (CONTINUED)**

#### STARTERS - I.E.C. STARTERS - 4L420

MOTOR	208 V	OLTS	OLTS 230 VOLTS		460 VOLTS	
HORSEPOWER	PART#	OPTION#	PART#	OPTION #	PART#	OPTION #
<sup>3</sup> / <sub>4</sub> & 1	4L420D	03	4L420D	03	4L420D	03
11/2	4L420D	03	4L420D	03	4L420D	03
2	4L420D	03	4L420D	03	4L420D	03
3	4L420D	03	4L420D	03	4L420D	03
5	4L420E	04	4L420D	03	4L420D	03
71/2	4L420G	05	4L420E	04	4L420D	03
10	4L420H	06	4L420G	05	4L420D	03
15	US	_	4L420H	06	4L420E	04
20	<b>★</b> NEMA 4L420G 05			05		
25			RATE	D		
30				9	STARTERS	

<u>PARTS ORDERING NOTE:</u> If the customer is replacing older starters with new starters (new part numbers listed above), they will also need to purchase new overload coils and auxiliary contacts.

**NOTE:** Use NEMA rated starters if dimensions are checked and will fit in panel.

Requirements for 208 volts: 15 hp or higher select 480 volt options as noted.

Requirements for 230 volts: 20 hp or higher select 480 volt options as noted.

\*Must see if NEMA starter will fit in panel. Give size if not quote IEC they will be higher cost.



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 17

### **ELECTRICAL COMPONENTS (CONTINUED)**

#### **OVERLOAD COILS - I.E.C. & NEMA STARTERS**

Motor Horospower	208 Volts	230 Volts	460 Volts
Motor Horsepower	Part Number	Part Number	Part Number
3/4	4L413H	4L416G	4L413E
1	4L413H	4L413H	4L413F
1½	4L413J	4L413J	4L413G
2	4L413K	4L413J	4L413G
3	4L413K	4L413K	4L413H
5	4L413M	4L413M	4L413K
7½	4L413N	4L413M	4L413K
10	4L413P	4L413N	4L413L
15	4L413R/X	4L413Q	4L413M
20	4L413R/X	4L413X/R	4L413N
25	4L413Y	4L413Y/T	4L413P
30	4L413Z	4L413Y	4L413W/Q
40	4L413Z	4L413Z	4L413X/R
50		4L413AA	4L413Y/T
60			4L413Y
75			4L413Z
100			4L413AA

<u>PARTS ORDERING NOTE:</u> If the customer is replacing older starters with new starters (new part numbers listed above), they will also need to purchase new overload coils.

Smith & Loveless, Inc.®

14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 18

### **ELECTRICAL COMPONENTS** (CONTINUED)

#### THREE PHASE MOTOR CIRCUIT BREAKERS -

Use when increasing or decreasing horsepower.

Motor HP	208 Volts	230 Volts	460 Volts
	Part Numbers	Parts Numbers	Parts Numbers
<sup>3</sup> / <sub>4</sub> & 1	4L202B	4L202B	4L258CA
1½	4L202B	4L202B	4L258CA
2	4L202B	4L202B	4L258CA
3	4L202C	4L202C	4L258CA
5	4L202F	4L202E	4L258CA
7½	4L202H	4L202H	4L258CB
10	4L202L	4L202K	4L258CE
15	4L202M	4L202M	4L258CG
20	4L202N	4L202N	4L258CH
25	4L164G	4L164G	4L258CJ
30	4L164G	4L164G	4L258CK
40	-	4L164G	4L258CL
50	-	-	4L164F
60	-	-	4L164G
75	-	-	4L164G

REQUIREMENTS FOR 208 VOLTS: 40 HP OR HIGHER SELECT 480 VOLT OPTIONS AS NOTED.

REQUIREMENTS FOR 230 VOLTS: 50 HP OR HIGHER SELECT 480 VOLT OPTIONS AS NOTED.

#### SINGLE PHASE MOTOR CIRCUIT BREAKERS -

Use when increasing or decreasing horsepower.

	230 Volts
Motor HP	Parts Numbers
1/4	4L218B
1/3	4L218B
1/2	4L218B
3/4	4L218B
1	4L218B
1½	4L218C
2	4L218E
3	4L218G
5	4L218J



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 19

### **ELECTRICAL COMPONENTS (CONTINUED)**

## BREAKERS – "QUICKLAG C" TYPE, SINGLE POLE, 5000 AMPERE INTERRUPTING CAPACITY, 120/240 VAC (TYPICALLY CONTROLS CIRCUIT BREAKER)

PART DESCRIPTION	PART #
5, Continuous Amp Rating	4L82A
10, Continuous Amp Rating	4L82B
15, Continuous Amp Rating	4L82C
20, Continuous Amp Rating	4L82D
25, Continuous Amp Rating	4L82E
30, Continuous Amp Rating	4L82F
35, Continuous Amp Rating	4L82G
40, Continuous Amp Rating	4L82H
50, Continuous Amp Rating	4L82J
55, Continuous Amp Rating	4L82K
60, Continuous Amp Rating	4L82L
70, Continuous Amp Rating	4L82M
100, Non-Automatic	4L82N
Handle Tie (California)	4L82P
30, Continuous MilliAmp Rating	4L82Q
5, Continuous MilliAmp Rating	4L82R

### BREAKERS – "QUICKLAG C" TYPE, AB DE-LON, 2 POLE, 10-100 AMPERES, 240 VAC

### (TYPICALLY TRANSFORMER CIRCUIT BREAKER OR SINGLE PHASE PUMP MOTORS)

PART DESCRIPTION	PART #
10, Continuous Amp Rating	4L218A
15, Continuous Amp Rating	4L218B
20, Continuous Amp Rating	4L218C
25, Continuous Amp Rating	4L218D
30, Continuous Amp Rating	4L218E
35, Continuous Amp Rating	4L218F
40, Continuous Amp Rating	4L218G
50, Continuous Amp Rating	4L218H
60, Continuous Amp Rating	4L218J
70, Continuous Amp Rating	4L218K
90, Continuous Amp Rating	4L218L
100, Continuous Amp Rating	4L218M
Breaker Handle Lock – "Quicklag C" Type	4L403
3 - 71	

<u>PARTS ORDERING NOTE</u>: Each time a Breaker is ordered as a part or with a retrofit, a Breaker Handle Lock is required.



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 20

### **ELECTRICAL COMPONENTS (CONTINUED)**

BREAKERS – "QUICKLAG C" TYPE, AB DE-LON, 2 POLE, 10-100 AMPERES, 480 VAC

### (TYPICALLY TRANSFORMER CIRCUIT BREAKER OR SINGLE PHASE PUMP MOTORS)

PART DESCRIPTION	PART #
15, Continuous Amp Rating	4L258BA
20, Continuous Amp Rating	4L258BB
25, Continuous Amp Rating	4L258BC
30, Continuous Amp Rating	4L258BD
35, Continuous Amp Rating	4L258BE
40, Continuous Amp Rating	4L258BF
45, Continuous Amp Rating	4L258BP
50, Continuous Amp Rating	4L258BG
60, Continuous Amp Rating	4L258BH
70, Continuous Amp Rating	4L258CJ
80, Continuous Amp Rating	4L258BK
90, Continuous Amp Rating	4L258BK
Breaker Handle Lock – "Quicklag C" Type	4L403

PARTS ORDERING NOTE: Each time a Breaker is ordered as a part or with a retrofit, a Breaker Handle Lock is required.



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 21

### **ELECTRICAL COMPONENTS** (CONTINUED)

BREAKERS – "QUICKLAG C" TYPE, AB DE-LON, 3 POLE, 10-100 AMPERES, 240 VAC

(TYPICALLY USED WITH 3 PHASE PUMP MOTORS 240 AND BELOW)

PART DESCRIPTION	PART #
10, Continuous Amp Rating *	4L202A **
15, Continuous Amp Rating	4L202B
20, Continuous Amp Rating	4L202C
25, Continuous Amp Rating	4L202D
30, Continuous Amp Rating	4L202E
35, Continuous Amp Rating	4L202F
40, Continuous Amp Rating	4L202G
45, Continuous Amp Rating	4L202P
50, Continuous Amp Rating	4L202H
55, Continuous Amp Rating	4L202J
60, Continuous Amp Rating	4L202K
70, Continuous Amp Rating	4L202L
80, Continuous Amp Rating	4L202Q
90, Continuous Amp Rating	4L202M
100, Continuous Amp Rating	4L202N
PART DESCRIPTION	PART#
Breaker Handle Lock – "Quicklag C" Type	4L403

PARTS ORDERING NOTE: Each time a Breaker is ordered as a part or with a retrofit, a Breaker Handle Lock is required.

MOUNTING STRAP FOR BREAKERS – "QUICKLAG C" TYPE		
PART DESCRIPTION PART #		
Mounting Strap	4L83	

<sup>\*</sup> Not UL Listed

<sup>\*\*</sup> Low Usage Item



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 22

#### **ELECTRICAL COMPONENTS** (CONTINUED)

BREAKERS – THERMAL MAGNETIC TYPE EHD, 1/2/3 POLE, 10-100 AMPS (15,000 AMPS INTERRUPTING CAPACITY)

#### (TYPICALLY USED WITH 3 PHASE PUMP MOTORS 480 VOLT)

AMP RATING @ 40°F (CONT.)	1-POLE 277 VAC (MAX.)	2-POLE 277 VAC (MAX.)	3-POLE 480 VAC (MAX.)
10 *	4L258AN **	4L258BN **	4L258CN **
15	4L258AA	4L258BA	4L258CA
20	4L258AB	4L258BB	4L258CB
25	4L258AC	4L258BC	4L258CC
30	4L258AD	4L258BD	4L258CD
35	4L258AE	4L258BE	4L258CE
40	4L258AF	4L258BF	4L258CF
50	4L258AG	4L258BG	4L258CG
60	4L258AH	4L258BH	4L258CH
70	4L258AJ	4L258CJ	4L258CJ
80	4L258AQ	4L258BK	4L258CQ
90	4L258AK	4L258BK	4L258CK
PART DESCRIPTION			PART #
Breaker Handle Lock – "EHD" Type			4L404

<u>PARTS ORDERING NOTE:</u> Each time a Breaker is ordered as a part or with a retrofit, a Breaker Handle Lock is **required**.

BREAKERS – MCP MOTOR CIRCUIT PROTECTOR, 3-POLE			
TRIP RANGE AMPS	<b>CONTINUOUS AMP RATING</b>	PART#	
100 – 300	30	4L164D	
160 – 480	50	4L164E	
275 – 1000	100	4L164F	
450 – 1550	150	4L164G	
Transformer	Breaker	4L218B	

<sup>\*</sup> Not UL Listed

<sup>\*\*</sup> Low Usage Item



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 23

#### **ELECTRICAL COMPONENTS (CONTINUED)**

**MOTORS - VERTICAL "P"** 

BASE PUMP MOTORS, TEFC, 3/60/230-460 VOLT

STANDARD SEAL

Call factory to determind correct motor requirements. Station serial number required.



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 24

### **ELECTRICAL COMPONENTS (CONTINUED)**

TEMPERATURE CONTROL (Thermodisc)	DADT"
PART DESCRIPTION	PART #
Temperature Control, 37° to 52° Heater	4L135B
Temperature Control, 90° to 75° Blower	4L135C
TIMER (also see Alternators)	
PART DESCRIPTION	PART#
Timer/Alternator for new stations, 2 Switches, Wire-in 16 Hour	
(8 on/off)	4L343 *
Replaces Zenith 4L282A)	
Timer/Alternator for new stations, 1 Switch, Wire-in 16 Hour	41.0054
8 on/off)	4L365A
Timer, 2 second delay (for Solenoid Valve, used with	41.406
Electrode Relay)	4L406
Electrode Relay)	
Timer (small blue) with knob, 8 pin, 0.1 sec – 10 min on delay  * PARTS ORDERING NOTE: Customer will require wiring installation instructions if	4L304A his replaces a 4L282/
Firmer (small blue) with knob, 8 pin, 0.1 sec – 10 min on delay  FARTS ORDERING NOTE: Customer will require wiring installation instructions if  FRANSFORMER	his replaces a 4L282 <i>i</i>
Timer (small blue) with knob, 8 pin, 0.1 sec – 10 min on delay  PARTS ORDERING NOTE: Customer will require wiring installation instructions if  TRANSFORMER  DESCRIPTION	his replaces a 4L282/
Firmer (small blue) with knob, 8 pin, 0.1 sec – 10 min on delay  FPARTS ORDERING NOTE: Customer will require wiring installation instructions if  FRANSFORMER  DESCRIPTION  2 KVA, 240/480 TO 120/240	his replaces a 4L282 <i>i</i>
Firmer (small blue) with knob, 8 pin, 0.1 sec – 10 min on delay  FPARTS ORDERING NOTE: Customer will require wiring installation instructions if  FRANSFORMER  DESCRIPTION  2 KVA, 240/480 TO 120/240  3 KVA, 240/480 TO 120/240	PART # 4L402A
Firmer (small blue) with knob, 8 pin, 0.1 sec – 10 min on delay  FPARTS ORDERING NOTE: Customer will require wiring installation instructions if  FRANSFORMER  DESCRIPTION  2 KVA, 240/480 TO 120/240  3 KVA, 240/480 TO 120/240  3 KVA, 208 TO 120/240	PART # 4L402A 4L402B
Timer (small blue) with knob, 8 pin, 0.1 sec – 10 min on delay	PART # 4L402A 4L402B 4L402D
Timer (small blue) with knob, 8 pin, 0.1 sec – 10 min on delay  FARTS ORDERING NOTE: Customer will require wiring installation instructions if  FRANSFORMER DESCRIPTION  KVA, 240/480 TO 120/240  KVA, 240/480 TO 120/240  KVA, 208 TO 120/240  KVA, 240/480 TO 120/240	PART # 4L402A 4L402B 4L402D 4L402E
Firmer (small blue) with knob, 8 pin, 0.1 sec – 10 min on delay  FPARTS ORDERING NOTE: Customer will require wiring installation instructions if  FRANSFORMER  DESCRIPTION  2 KVA, 240/480 TO 120/240  3 KVA, 240/480 TO 120/240  3 KVA, 208 TO 120/240  5 KVA, 240/480 TO 120/240  5 KVA, 240/480 TO 120/240	PART # 4L402A 4L402B 4L402D 4L402E
Fimer (small blue) with knob, 8 pin, 0.1 sec – 10 min on delay  FPARTS ORDERING NOTE: Customer will require wiring installation instructions if  FRANSFORMER DESCRIPTION  EVAN WAY SECOND SECON	PART # 4L402A 4L402B 4L402B 4L402E 4L402EA
Firmer (small blue) with knob, 8 pin, 0.1 sec – 10 min on delay  FPARTS ORDERING NOTE: Customer will require wiring installation instructions if  FRANSFORMER  DESCRIPTION  E KVA, 240/480 TO 120/240  B KVA, 240/480 TO 120/240  B KVA, 208 TO 120/240  E KVA, 240/480 TO 120/240  E KVA, 240/480 TO 120/240  E KVA, 208 TO 120/240  E KVA, 208 TO 120/240  E KVA, 208 TO 120/240  SWITCHES  PART DESCRIPTION  Alternator Selector Switch (4L207A, replaced by 4L23)	PART # 4L402A 4L402B 4L402B 4L402E 4L402EA
Firmer (small blue) with knob, 8 pin, 0.1 sec – 10 min on delay  FPARTS ORDERING NOTE: Customer will require wiring installation instructions if  FRANSFORMER  DESCRIPTION  E KVA, 240/480 TO 120/240  B KVA, 240/480 TO 120/240  B KVA, 208 TO 120/240  E KVA, 240/480 TO 120/240  E KVA, 240/480 TO 120/240  B KVA, 208 TO 120/240  E KVA, 208 TO 120/240  SWITCHES  PART DESCRIPTION  Alternator Selector Switch (4L207A, replaced by 4L23)  Float Switch (P/N 87A80 Obsolete, Replaced by 4L291A)	PART # 4L402B 4L402B 4L402E 4L402E 4L402EA
Finner (small blue) with knob, 8 pin, 0.1 sec – 10 min on delay  FPARTS ORDERING NOTE: Customer will require wiring installation instructions if  FRANSFORMER  DESCRIPTION  ENVA, 240/480 TO 120/240  ENVA, 240/480 TO 120/240  ENVA, 208 TO 120/240  ENVA, 240/480 TO 120/240  ENVA, 208 TO 120/240  ENVA, 208 TO 120/240  ENVA, 208 TO 120/240  ENVALUATION  ENVAL	PART # 4L402A 4L402B 4L402D 4L402E 4L402EA  PART # See 4L23 4L291A
Firmer (small blue) with knob, 8 pin, 0.1 sec – 10 min on delay  FPARTS ORDERING NOTE: Customer will require wiring installation instructions if  FRANSFORMER DESCRIPTION  E KVA, 240/480 TO 120/240  B KVA, 240/480 TO 120/240  B KVA, 208 TO 120/240  E KVA, 240/480 TO 120/240  E KVA, 240/480 TO 120/240  E KVA, 208 TO 120/240  E KVA, 208 TO 120/240  E KVA, 208 TO 120/240	PART # 4L402A 4L402B 4L402B 4L402E 4L402EA  PART # See 4L23 4L291A 4L291A
Fimer (small blue) with knob, 8 pin, 0.1 sec – 10 min on delay  FPARTS ORDERING NOTE: Customer will require wiring installation instructions if  FRANSFORMER  DESCRIPTION  ENVA, 240/480 TO 120/240  ENVA, 240/480 TO 120/240  ENVA, 240/480 TO 120/240  ENVA, 208 TO 120/240  ENVA, 240/480 TO 120/240  ENVA, 240/480 TO 120/240  ENVA, 240/480 TO 120/240  ENVA, 208 TO 120/240  ENVA, 208 TO 120/240  ENVA, 208 TO 120/240  ENVA DESCRIPTION  Alternator Selector Switch (4L207A, replaced by 4L23)  Float Switch (P/N 87A80 Obsolete, Replaced by 4L291A)  Float Switch (Normally Open Blue), 30 ft. cord  Float Switch (Normally Closed Red), 30 ft. cord	PART # 4L402B 4L402B 4L402E 4L402E 4L402EA  PART # See 4L23 4L291A 4L291B

#### **VOLTAGE SUPPRESSOR**

Station Flooding Pressure Switch

Toggle Switch (On/Off), SPST (Not UL Listed)

Thermostat Switch for Heater

#### PART DESCRIPTION

Non mercury float switch

(replaces 4L207A)

Voltage Suppressor 4L139A - No longer used or required. Need to upgrade electrode relays to PN: 4L408H.

**OBSOLETE** 

4L178

4L23A

4L291F

**OBSOLETE** 



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 25

### **MECHANICAL, PIPING, & PARTS**

PUMP PARTS	4B2B*1 Pump	TURBO 4B2C Pump	4B2D*1 Pump
VERIFY ALL CASTED PARTS WITH FACTORY Shaft Diameter	17/8"	17/8"	17/8"
Impeller, CW (Clockwise)	60B265A	87D103	60B269A
Impeller, CCW (Counter-Clockwise)	60B265B	87D103	60B269B
Maximum Diameter	10½8"	101/8"	101/8"
Suction Side - Diameter Eye	4"	4"	4"
Front Head	87C1-300	Part of Volute	4"- 87C1-300
Pump Stand	None	None	None
Volute (Some pumps have integral front heads. Call Factory before ordering to verify.)	87D3-300	60D230-300 (CW) 60D231-300 (CCW)	87D3-300
Volute Gasket (1/64 & 1/16 thickness available)	60A26 (1/32")	60A26 (1/32")	60A26 (1/32")
Volute/Elbow Gasket (Rectangular)	87A11	87A11	87A11
Volute/Base Gasket (Replaces 87A63)	60A108	60A108	60A108
Motor Adapter – Also sell S/N NAMEPLATE	60B165A-300	60B165A-300	60B165A-300
Impeller Bolt	60A12	60A12	60A12
Impeller Washer	60A20	60A20	60A20
PUMP PARTS VERIFY ALL CASTED PARTS WITH FACTORY	4B3B*1 Pump	4C2B*1 Pump	4C2D*1 Pump
Shaft Diameter	17⁄8"	21/8"	21/8"
Impeller, CW (Clockwise)	60B272A	60B265C	60B269C
Impeller, CCW (Counter-Clockwise)	60B272B	60B265D	60B269D
Maximum Diameter	12"	101/8"	101/8"
Suction Side - Diameter Eye	4"	4"	4"
	4" - 60C85-300	4" - 87C1-300	4" - 87C1-300
Front Head	6" - 60C87-300	87C200-300 **	87C200-300 **
		60C156-300 ***	60C156-300 ***
Pump Stand	None	None	None
Valuta (o	None	110110	
VOIUTE (Some pumps have integral front heads, Call		60D7-300 <b>**</b>	60D7-300 <b>**</b>
VOIUTE (Some pumps have integral front heads. Call Factory before ordering to verify.)	87D133-300	60D7-300 <b>**</b>	60D7-300 <b>**</b> 87D3-300
Volute (Some pumps have integral front heads. Call Factory before ordering to verify.)  Volute Gasket (1/64 & 1/16 thickness available)			
Factory before ordering to verify.)  Volute Gasket (1/64 & 1/16 thickness available)	87D133-300	60D7-300 <b>**</b> 87D3-300	87D3-300
Factory before ordering to verify.)  Volute Gasket (1/64 & 1/16 thickness available)  Volute/Elbow Gasket (Rectangular)	87D133-300 60A28 (1/32")	60D7-300 <b>**</b> 87D3-300 60A26 (1/32")	87D3-300 60A26 (1/32")
Factory before ordering to verify.)	87D133-300 60A28 (1/32") 87A11	60D7-300 <b>**</b> 87D3-300 60A26 (1/32") 87A11	87D3-300 60A26 (1/32") 87A11
Factory before ordering to verify.)  Volute Gasket (1/64 & 1/16 thickness available)  Volute/Elbow Gasket (Rectangular)  Volute/Base Gasket (Replaces 87A63)	87D133-300 60A28 (1/32") 87A11 60A108	60D7-300 **  87D3-300  60A26 (1/32")  87A11  60A108	87D3-300 60A26 (1/32") 87A11 60A108

<sup>\*</sup>Used only for 20 HP @ 1800 RPM Motors

PARTS ORDERING NOTE: Remind customer that gaskets may be needed when ordering casted parts

<sup>\*\*</sup>Used on 4\_2\_ pumps in 3-pump WWMPS

<sup>\*\*\*</sup> Used on 4\_2\_ pumps in 2-Pump WMPS



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 26

### MECHANICAL, PIPING, & PARTS (CONTINUED)

PUMP PARTS	4C3B*1	4D3B*1	4D4B
VERIFY ALL CASTED PARTS WITH FACTORY	Pump	Pump	Pump
Shaft Diameter	21/8"	3"	3"
Impeller, CW (Clockwise)	60B272C	60B272E	60D259
Impeller, CCW (Counter-Clockwise)	60B272D	60B272F	60D258
Maximum Diameter	12"	12"	15"
Suction Side - Diameter Eye	4"	4"	6"
Front Head	4" - 60C85-300 6" - 60C87-300	4" - 60C85-300 6" - 60C87-300	4" - n/a 6" - 60B124-300
Pump Stand	None	None	None
Volute (Some pumps have integral front heads. Call Factory before ordering to verify.)	87D133-300	87D133-300	60D252-300
Volute Gasket (1/64 & 1/16 thickness available)	60A28 (1/32")	60A28 (1/32")	60A106B (1/32")
Volute/Elbow Gasket (Rectangular)	87A11	87A11	87A11
Volute/Base Gasket (Replaces 87A63)	60A108	60A108	60A108
Motor Adapter – Also sell S/N NAMEPLATE	60B165E-300****	60B165M-300	60B165Q-300
Impeller Bolt	60A12	60A87	60A87
Impeller Washer	60A20	60A86	60A86

<sup>\*\*\*\*\*</sup>Consult the Factory for 20HP, 1800 RPM Motors

PUMP PARTS  VERIFY ALL CASTED PARTS WITH FACTORY	6B3B*1 Pump	6B3B*1(Series) Pump	6C3B*1 Pump
Shaft Diameter	17/8"	17/8"	21/8"
Impeller, CW (Clockwise)	60B273A	60B273A	60B273C
Impeller, CCW (Counter-Clockwise)	60B273B	60B273B	60B273D
Maximum Diameter	12"	12"	12"
Suction Side - Diameter Eye	51/8"	51/8"	51/8"
Front Head	60C88-300	87C94-300 *	60C88-300
Pump Stand	None	None	None
Volute (Some pumps have integral front heads. Call Factory before ordering to verify.)	87D78-300	60D35-300 <b>*</b>	87D78-300
Volute Gasket (1/64 & 1/16 thickness available)	60A28 (1/32")	60A28 (1/32")	60A28 (1/32")
Volute/Elbow Gasket (Rectangular)	87A11	87A11	87A11
Volute/Base Gasket (Replaces 87A63)	60A108	60A108	60A108
Motor Adapter – Also sell S/N NAMEPLATE	60B165D-300	60B165D-300 *	60B165E-300 60B165F-300
Impeller Bolt	60A12	60A12	60A12
Impeller Washer	60A20	60A20	60A20

<sup>\*</sup> Differences in **Series** Pump

<u>PARTS ORDERING NOTE:</u> Remind customer that gaskets may be needed when ordering casted parts



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 27

### MECHANICAL, PIPING, & PARTS (CONTINUED)

PUMP PARTS	6C3B*1(Series)	6D3B*1	6D3B*1(Series)
VERIFY ALL CASTED PARTS WITH FACTORY	Pump	Pump	Pump
Shaft Diameter	21/8"	3"	3"
Impeller, CW (Clockwise)	60B273C	60B273E	60B273E
Impeller, CCW (Counter-Clockwise)	60B273D	60B273F	60B273F
Maximum Diameter	12"	12"	12"
Suction Side - Diameter Eye	51/8"	5½"	51/8"
Front Head	87C94-300 *	60C88-300	87C94-300 *
Pump Stand	None	None	None
Volute (Some pumps have integral front heads. Call Factory before ordering to verify.)	60D35-300 *	87D78-300	60D35-300 <b>*</b>
Volute Gasket (1/64 & 1/16 thickness available)	60A28 (1/32")	60A28 (1/32")	60A28 (1/32")
Volute/Elbow Gasket (Rectangular)	87A11	87A11	87A11
Volute/Base Gasket (Replaces 87A63)	60A108	60A108	60A108
Motor Adoptor Alexant O/ALNAMEDIATE	60B165E-300 *	60B165M-300	60D16EM 202 +
Motor Adapter – Also sell S/N NAMEPLATE	60B165F-300 *	00D 103IVI-300	60B165M-300 *
Impeller Bolt	60A12	60A87	60A87
Impeller Washer	60A20	60A86	60A86

PUMP PARTS  VERIFY ALL CASTED PARTS WITH FACTORY	8C4D Pump	8D4D Pump
Shaft Diameter	21/8"	3"
Impeller, CW (Clockwise)	60D178	60D150
Impeller, CCW (Counter-Clockwise)	60D179	60D151
Maximum Diameter	15"	15"
Suction Side - Diameter Eye	7"	7"
Front Head	8" - 60C155-300	8" - 60C155-300
Pump Stand	None	None
Volute (Some pumps have integral front heads. Call Factory before ordering to verify.)	60D211-300	60D211-300
Volute Gasket (1/64 & 1/16 thickness available)	60A106B (1/32")	60A106B (1/32")
Volute/Elbow Gasket (Rectangular)	87A11	87A11
Volute/Base Gasket (Replaces 87A63)	60A108	60A108
Motor Adapter – Also sell S/N NAMEPLATE	60B165P-300	60B165P-300
Impeller Bolt	60A12	60A87
Impeller Washer	60A20	60A86

<sup>\*</sup> Differences in Series Pump

PARTS ORDERING NOTE: Remind customer that gaskets may be needed when ordering casted parts



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 28

### MECHANICAL, PIPING, & PARTS (CONTINUED)

#### **MECHANICAL SEALS - SINGLE**

CEAL & CDADE DADTO	B-SHAFT	C-SHAFT	D-SHAFT
SEAL & SPARE PARTS	17/8"	21/8"	3"
Seal Kit, Single Mechanical Seal	H87A28	H87A97	H87A534
Bronze Seal Housing	87B2	87B19***	87B73***
Seal Housing – Flat Gasket **	60A11	60A17	60A84
Seal Housing – Quad Ring **	60A110	60A111	60A146
Ceramic Rotating Wear Ring	60A32 *	60A33 *	60A85 *
Carbon Stationary Wear Ring	60A36 *	60A37 *	60A52 *
Rotating O-Ring	60A39 *	60A41 *	60A53 *
Stationary Quad Ring	60A38 *	60A40 *	60A54 *
Spring	60A30 *	60A31 *	60A55 *
Impeller Bolt	60A12	60A12	60A87
Impeller Washer	60A20	60A20	60A86
Volute Gasket	See Volute Gasket Table		

\* Parts contained in H87A28, H87A97, or H87A182 Mechanical Seal Kits

<u>PARTS ORDERING NOTE:</u> Each time the impeller bolt is removed (required for seal replacement), Smith & Loveless recommends installation of a new impeller bolt that has the embedded Nylock.

<u>PARTS ORDERING NOTE:</u> Each time a new seal, ceramic, carbon or spring is installed, a volute gasket, seal housing gasket or quad ring, and impeller bolt are recommended.

<sup>\*\* &</sup>lt;u>PARTS TIP:</u> Seal Housing – Flat Gasket vs. Quad Ring: The older seal housing has a flat surface and uses the flat gasket for both the single and double mechanical seals. The newer seal housing has a groove and it can use either the flat gasket or the quad ring.

<sup>\*\*\*</sup>SEAL HOUSING: Call factory for different seal housings for 4-frame pumps.(4B4B, 6C4V)

<sup>\*\*\*\*</sup>BOLDED PARTS: Always quote all bolded parts when quoting a mechanical seal kit.



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 29

#### MECHANICAL, PIPING, & PARTS (CONTINUED)

### DOUBLE BALANCED (FOR OVER 200' TDH\*\*\*\*) MECHANICAL SEALS

SEAL & SPARE PARTS (HIGH HEAD SEALS – For Over 200' TDH**** or Series P.S.)	C-SHAFT 2-1/8"	D-SHAFT 3"
Seal Kit, Mechanical Seal – Double Balanced (DOES NOT INCLUDE BALANCE SLEEVE)	H60A156	H60A137
Complete Assembly including Bronze Seal Housing & Mechanical Seal (Parts include Upper Housing thru Lower Housing) (Order one extra Seal Housing Quad Ring)	87C425	87C427
Bronze Seal Housing, Upper	87C424	87C428
Bronze Seal Housing, Lower	60C95	60C97
Seal Housing Gasket - Flat ***	60A17	60A84
Seal Housing Gasket - Quad Ring ***	60A111	60A112
Ceramic Rotating Wear Ring (requires 2)	60A155 *	60A85 *
Carbon Stationary Wear Ring (requires 2)	60A153 *	60A136 *
Stationary Quad Ring (requires 2)	11L47E *	60A54 *
Spring	60A154 *	60A135 *
O-Ring-Balance Sleeve, Inner (D-Shaft – new style sleeve 60C112/B requires 2, old style sleeve 60C112/A requires 1)	11L207C *	11L207A *
O-Ring Balance Sleeve, Outer (Both old & new require two out O-Rings)	11L207D *	11L207B *
Balance Sleeve	60B259**	60B277 <b>**</b>
Impeller Bolts	60A12	60A87
Impeller Washer	60A20	60A86
Volute Gaskets	See the Volute Gasket Table	

**BOLDED PARTS**: Always quote all bolded parts when quoting a mechanical seal kit.

<u>PARTS ORDERING NOTE:</u> Each time the impeller bolt is removed (required for seal replacement), Smith & Loveless recommends installation of a new impeller bolt that has the embedded Nylock.

<u>PARTS ORDERING NOTE:</u> Each time a new seal, ceramic, carbon or spring is installed, a volute gasket, seal housing gasket or quad ring, and impeller bolt are recommended.

\*\*\* <u>PARTS TIP:</u> Seal Housing – Flat Gasket vs. Quad Ring: The older seal housing has a flat surface and uses the flat gasket for both the single and double mechanical seals. The newer seal housing has a groove and it can use either the flat gasket or the quad ring.

<sup>\*</sup> Parts contained in H60A156 or H60A137 Double Balanced Mechanical Seal Kits

<sup>\*\*</sup> PARTS ORDERING NOTE: Each time the balance sleeves are replaced, new Balance Sleeve O-Rings are recommended.

NOTE: Series 4 Pump C&D Shaft WWMPS-See Factory. High Head Seals on Second Stage Pumps may be required For Over 200'TDH. Add Pump 1 & Pump 2 TDH together to determine if more than 200'TDH. See Factory.



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 30

### MECHANICAL, PIPING, & PARTS (CONTINUED)

GASKETS, VOLUTE PUMP SIZE	STANDARD GASKET PART #	OTHER GASKETS 1/64" & 1/16" THICKNESS
4B2B*1, TURBO 4B2C, 4B2D, 4C2B, 4C2D	<b>60A26</b> (1/32")	60A27 (1/16")
4B3B, 4C3B, 4D3B, 6B3B (& SERIES), 6C3B (& SERIES), 6D3B(& SERIES)	<b>60A28</b> (1/32")	60A29 (1/16")
4D4B	60 A 4 0 G D (4 /0 O 2)	60A106A (1/64")
4D4D	<b>60A106B</b> (1/32")	60A106C (1/16")
9C4D 9D4D	COA40CD (4/00%)	60A90 (1/64")
8C4D, 8D4D	<b>60A106B</b> (1/32")	60A89 (1/16")

<u>PARTS ORDERING NOTE:</u> New volute gasket is required each time the rotating assembly (motor, impeller, mechanical seals, &/or volute) is disassembled.

#### PUMP IMPELLERS & PUMP X-PELLERS® - VACUUM PRIMED

PUMP MODEL	MOTOR	IMPELLER	IMPELLER	ADDITIONAL PARTS
POWP WIODEL	RPM	CW PART #	CCW PART #	1 SET PER IMPELLER PART#
4B2B*1	-	60B265A	60B265B	60A12, 60A20, 60A26
TURBO 4B2C	-	87D103	87D104	60A12, 60A20, 60A26
4B2D*1	-	60B269A	60B269B	60A12, 60A20, 60A26
4B2X*1	-	60B252A	60B252B	60A12, 60A20, 60A26
4B3B*1	-	60B272A	60B272B	60A12, 60A20, 60A28
4C2B*1	-	60B265C	60B265D	60A12, 60A20, 60A26
4C2D*1	-	60B269C	60B269D	60A12, 60A20, 60A26
4C2X*1	-	60B252C	60B252D	60A12, 60A20, 60A26
4C3B*1	-	60B272C	60B272D	60A12, 60A20, 60A28
4D3B*1	-	60B272E	60B272F	60A87, 60A86, 60A28
4D4B	-	60D259	60D258	60A87, 60A86, 60A106B
6B3B*1 (& SERIES)	-	60B273A	60B273B	60A12, 60A20, 60A28
6B3X	-	60B204	60B209	60A12, 60A20, 60A28
6C3B*1 (& SERIES)	-	60B273C	60B273D	60A12, 60A20, 60A28
6C3X	-	60B217	60B218	60A12, 60A20, 60A28
6D3B*1 (& SERIES)	-	60B273E	60b273F	60A87, 60A86, 60A28
6D3X	-	60B219	60B220	60A87, 60A86, 60A28
8C4D	-	60D178	60D179	60A12, 60A20, 60A106B
8D4D	-	60D150	60D151	60A87, 60A86, 60A106B

<u>PARTS ORDERING NOTE</u>: When ordering & replacing standard impeller with \*1 IMPELLER or **X-PELLER**® call factory for sizing & trim

requirements.



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 31

#### **OTHER PARTS**

ANODE PACK		
PART DESCRIPTION		PART #
Magnesium Anode pack - 17 ll	os. w/30' lead (Total Weight = 45 lbs.)	12L8
Anode Test Box		Call Retrofit
BLOWER		
PART DESCRIPTION		PART#
Blower – 265 CFM (Newer St	ations)	7L195
Blower – 110 CFM (Older Sta	ations)	7L40
Louver for Vent in Hood		11L138A
Seal for Louver (Placed betwe	en louver & fiberglass)	87A86
DEHUMIDIFIER		
PART DESCRIPTION		PART#
Dehumidifier - 115V, 45 Pints բ	oer Day – Freestanding	11L150L
EMERGENCY KIT		
PART DESCRIPTION		PART #
	Normally Open:	4L291A
Float Switch <b>*</b>		
	Normally Closed:	4L291B
Control Relay	Normally Closed:	4L291B 4L107F
Control Relay Electrode Relay	Normally Closed:	
<u> </u>	Normally Closed:	4L107F 4L408Q
Electrode Relay Mechanical Seal	Normally Closed:	4L107F 4L408Q (see page 28)
Electrode Relay		4L107F 4L408Q (see page 28) 1L406K, 1L545/
Electrode Relay  Mechanical Seal  Solenoid Valve *  Vacuum Dome (replaces 87B1		4L107F 4L408Q (see page 28) 1L406K, 1L545
Electrode Relay  Mechanical Seal  Solenoid Valve *  Vacuum Dome (replaces 87B1  PARTS ORDERING NOTE: Small O-F	33, 87B133A)	4L107F 4L408Q (see page 28) 1L406K, 1L545/ or 1L545B
Electrode Relay  Mechanical Seal  Solenoid Valve *  Vacuum Dome (replaces 87B1  PARTS ORDERING NOTE: Small O-Frecommended (not included with dome).	33, 87B133A)	4L107F 4L408Q (see page 28) 1L406K, 1L5456 or 1L545B

<sup>\*</sup> SELECT THE PART(S) NEEDED FOR THE SPECIFIC INSTALLATION

<sup>\*\*</sup> SEE SECTION 6 FOR COMBINED EXHAUST CONFIGURATION



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 32

### **OTHER PARTS (CONTINUED)**

GASKETS		
PART DESCRIPTION		PART #
4" & 6" Volute/Discharge Elbow Gasket (Rectangular)		87A11
4" Flange Gasket (check valves & suction/discharge pipin	ıg)	11L1A
6" Flange Gasket (check valves & suction/discharge pipin	ıg)	11L1C
8" Flange Gasket (check valves & suction/discharge pipin	ıg)	11L1D
10" Flange Gasket (check valves & suction/discharge pip	ing)	11L1E
12" Flange Gasket (check valves & suction/discharge pip	ing)	11L1F
14" Flange Gasket (check valves & suction/discharge pip	ing)	11L1G
Volute/Base Gasket (Replaces 87A63 O-Ring)		60A108
	B Shaft:	60A11
Seal Housing Gasket - Flat *	C Shaft:	60A17
	D Shaft:	60A84
	B Shaft:	60A110
Seal Housing Gasket - Quad Ring *	C Shaft:	60A111
	D Shaft:	60A146

<sup>\* &</sup>lt;u>PARTS TIP:</u> Seal Housing Gasket - Flat vs. Quad Ring: The older seal housing has a flat surface and uses the flat gasket for both the single and double mechanical seals. The newer seal housing has a groove and it can use either the flat or the quad ring gasket.

GASKETS, VOLUTE PUMP SIZE	STANDARD GASKET PART #	OTHER GASKETS 1/64" & 1/16" THICKNESS
4B2B*1, TURBO 4B2C, 4B2D, 4C2B, 4C2D	<b>60A26</b> (1/32")	60A27 (1/16")
4B3B, 4C3B, 4D3B, 6B3B (& SERIES), 6C3B (& SERIES), 6D3B(& SERIES)	<b>60A28</b> (1/32")	60A29 (1/16")
4D4B	<b>60A106B</b> (1/32")	60A106A (1/64") 60A106C (1/16")
8C4D, 8D4D	<b>60A106B</b> (1/32")	60A90 (1/64")
		60A89 (1/16")

<u>PARTS ORDERING NOTE:</u> New volute gasket is required each time the rotating assembly (motor, impeller, mechanical seals, &/or volute) is disassembled.

GAUGES, AIR PRESSURE	
PART DESCRIPTION	PART#
0 – 60 PSI with 3½" Dial	1L84E
0 – 60 PSI with 4½" Dial	1L84H



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 33

### **OTHER PARTS (CONTINUED)**

GLYCERIN-FILLED	
PART#	
1L780B*	
1L780C*	
1L780D*	
1L372A	

<sup>\* 3-1/2&</sup>quot; diameter dial (Customer must verify fit. If smaller dial is needed, contact factory)

PARTS ORDERING TIP: If no gauge is currently in use, order 1L780C. Consult Factory

GAUGE, WATER	
PART DESCRIPTION	PART #
0 – 200 Inches with 2½" Dial	1L119D

HOOD	'
PART DESCRIPTION	PART #
Fiberglass Hood - MUST also sell S/N NAMEPLATE	Consult Factory
<u>NOTE:</u> Hardware (louvers, hinges, & handle) not included requested separately.	d with the hood - must be

**NOTE TO REPS**: PLEASE BE SURE TO OFFER HOOD LIFT ASSIST AND CONTINUOUS HINGE & BACKING BAR RETROFIT KITS WHEN REPLACING A HOOD

HOOD (FIBERGLASS) REPAIR KIT	
PART DESCRIPTION	PART #
Fiberglass Hood Repair Kit (1 pt. S&L light green gel coat,	
1 pt. Polyester resin, 3 sq. ft. fiberglass mat.)	Call Factory
Recommend selling s/n name plate at same time.	



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 34

### **OTHER PARTS (CONTINUED)**

KEYSTOCK (MOTOR SHAFT KEY)	
PART DESCRIPTION	PART#
B Shaft	95L39-0
C Shaft	95L39-0
D Shaft	95L39-01

LOUVER – VENT IN HOOD	
PART DESCRIPTION	PART #
Louver for Vent in Hood	11L138A
Seal for Louver (Placed between louver & fiberglass)	87A86
Blower – 265 CFM (Newer Stations)	7L195
Blower – 110 CFM (Older Stations)	7L40

NAME PLATE, FOR S&L SERIAL NUMBER	
PART DESCRIPTION	PART #
Name Plate for Hood	OBSOLETE
Name Plate for Motor Adapter (includes addition of GPM @ ' TDH)	OBSOLETE

O&M'S	
PART DESCRIPTION	PART #
O&M's – Requires Job Serial Number	O&MMANUAL

PAINT (VERSAPOX®) & TOUCH-UP KITS	
PART DESCRIPTION	PART#
Aquamarine VERSAPOX®, Part A, Gallon	12L181B *
Light Green VERSAPOX®, Part A, Gallon	12L109B *
Dark S&L Green <b>VERSAPOX®</b> , Part A, Gallon	12L104B *
Catalyst, VERSAPOX®, Part B, Gallon	12L105B
Primer (RED), Part A, Gallon	12L138A *
Primer Catalyst, Part B, Gallon	12L138B
Touch-Up Paint Kit – Aquamarine	H87A424
Touch-Up Paint Kit – Light Green	H87A426
Touch-Up Paint Kit – Georgian Hemlock	H87A425

<sup>\*</sup> Order one gallon of Catalyst Part B for each gallon of paint/primer – must be mixed before use.



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 35

### **OTHER PARTS (CONTINUED)**

RECTANGULAR GASKETS	
PART DESCRIPTION	PART #
4" & 6" Volute/Discharge Elbow Gasket (Rectangular)	87A11
SAFETY EQUIPMENT	
PART DESCRIPTION	PART #
SAF-T-BELT	11L220
SAF-T-LANYARD	11L220A
SAF-T-HARNESS	11L220B
SHADE AIDE™ (HMI SCREEN SUN BLOCKER)	
PART DESCRIPTION	PART#
SHADE AIDE™ Kit, Small / Aluminium (covers HMI Screen 9.5" W x 7" H)	H87A379-4
SHADE AIDE™ Kit, Small Stainless Steel	H87A379-4X
(covers HMI Screen 9.5" W x 7" H)	11077373-47
SHADE AIDE™ Kit, Large Aluminium	H87A485-4
(covers HMI Screen 15" W x 11" H)	11077400-4
SHADE AIDE™ Kit, Large Stainless Steel	H87A485-4X
(covers HMI Screen 15" W x 11" H)	11077405-47
SHADE AIDE™ Kit, Extra Large Aluminium	H87A503A-4
(covers HMI Screen 19.875" W x 14" H)	1107 A303A-4
SHADE AIDE™ Kit, Extra Large Stainless Steel	H87A503D-4
(covers HMI Screen 19.875" W x 14" H)	110770000-4
SLINGER RINGS (FOR MOTORS)	
PART DESCRIPTION	PART #
B Shaft	95L39-B*
C Shaft	95L39-C*
D Shaft	95L39-D*
SUMP PUMPS	
PART DESCRIPTION	PART #
Sump Pump, ½ HP, use with Float Switch 8L43AA	8L43A
Float Switch for 8L43A Sump Pump	8L43AA
Sump Pump, high-capacity, ½ HP (Replaces 8L1)	8L47
Sump Pump, .3 HP (Replaces 8L9)	8L53A
Screen, Sump Pump 10" tall	28B153B
VIDEOD TRAINING	
VIDEOS - TRAINING PART DESCRIPTION	PART#
How To Replace the Single Mechanical Seal – DVD Format	12L318DVD-

<sup>\*</sup>PARTS ORDERING NOTE: Part # extension varied based on manufacturer. Motor manufacturer needs to be identified prior to sale.



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 36

#### **VACUUM PRIMING SYSTEM**

DELAY TIMER - SONIC START® STREAMLINE™	
PART DESCRIPTION	PART #
SONIC START ® STREAMLINE™ Delay Timer – Required for	
SONIC START® STREAMLINE™	4L406B
Comes standard in the H87A391J & H87A457 upgrade kits.	
ELECTRODE DOMES – VACUUM DOMES	
PART DESCRIPTION	PART #
	0=D 400D det

ELECTRODE DOMES – VACUUM DOMES		
PART DESCRIPTION	PART #	
Electrode Dome (one hole at top)	87B133B **	
Vacuum Dome (one hole at top)	87B133B **	
Aluminum Electrode Dome (two holes at top) (old P/N 87B15 no longer available, order H87A329A 1st time for conversion to electrode or H87A391P for conversion to WaveStart®.)	OBSOLETE (Order H87A329A)	

<sup>\*\*</sup>PARTS ORDERING NOTE: Small O-Ring (P/N 11L4J) & Large O-Ring (11L4k) are recommended (not included with dome)

FLECTRODE DOME ACCEMBLIES VACUUM DOME ACC	SEMBLIES.
ELECTRODE DOME ASSEMBLIES – VACUUM DOME ASSEMBLIES	
PART DESCRIPTION	PART #
Electrode Dome Assembly with new style SOLID Stainless Steel <b>5</b> 1/4" long Electrode and Quick Disconnect Fitting	87B309B *
(Can be used to replace the obsolete 87B134B & 87B309 assemblies)	
Electrode Dome Assembly with new style SOLID Stainless Steel <b>6"</b> Long Electrode and Quick Disconnect Fitting.	87B309C *
(Can be used to replace the obsolete <b>87B134A &amp; 87B309A</b> assemblies)	
* Ferrule Connection Fitting	
(OPTIONAL replacement for Quick Disconnect Fitting on new style electrodes that are included with these assemblies/kits)	1L248A
SONIC START® Vacuum Dome Complete Assembly	87B452A
SONIC START® STREAMLINE™ or WaveStart® for Pump Stations Vacuum Dome Assembly (includes vacuum dome + 2-way solenoid valve & interconnecting piping to make assembly.)  SPECIAL NOTE: Solenoid has DIN connector w/cable connection.	87B728
<b>Blank Vacuum Dome Assembly</b> (only use with 4-pump series vacuum primed pump stations and only on pump not regulating wet well flow. List of parts A-I required to make assembly.	
A. Vacuum Dome (1 required)	87B133B**
B. Bulk Head Union (1 required)	1L481C
C. Stainless Steel Nut (2 required)	6L30K
D. Large O-Ring (1 required)	11L47K
E. Stainless Steel Stud (2 required)	6L200DE
F. Stainless Steel Flat Washer (2 required)	6L65F
G. Dome Compression Ring (1 required)	87A226
H. O-Ring (1 required)	11L4J
I. Cap for Bulkhead Union (1 required)	1L481CA



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 37

#### **VACUUM PRIMING SYSTEM**

(ITS PART#
yle de H87A329A
H87A391P
OBSOLETE
OBSOLETE
<sup>on</sup> 1L248A
H87A391P
OBSOLETE
PART #
4L29
5L49B
OBSOLET
4L408Q
5L49B
ch B nollow OBSOLET

<u>PARTS ORDERING TIP:</u> Hollow electrode parts for obsolete assemblies 87B134A & 87B134B available individually



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 38

#### **VACUUM PRIMING SYSTEM (CONTINUED)**

### ELECTRODES (OLD TECHNOLOGY – STATE-OF-THE-ART IS SONIC START® PROBE)

PART DESCRIPTION	PART#
Solid Aluminum Electrode (old P/N 87A72 no longer available)  Convert to Solid Electrode with Kit H87A329A or SONIC START® STREAMLINE™ Dome Retrofit  Adapter Piece PN 87A225 & Hardware or the WaveStart ® Conversion kit H87A391P	OBSOLETE
Hollow SS Electrode, 57/8" Long (old P/N 87A229A no longer available Order 87B309C as replacement)	OBSOLETE
Hollow SS Electrode, 5" Long <b>ONLY</b> (Available until current stock is depleted) Convert to PN 87A285 + Bulk Head Fittings or <b>WaveStart</b> ®	87A229B *
5½ Long Solid Stainless Steel Electrode <b>ONLY</b> Recommend Converting to low maintenance <b>WaveStart</b> ®	87A285 <b>*</b>
51/4" Long Solid Stainless Steel Electrode Dome Complete Assembly Recommend Converting to low maintenance WaveStart®	87B309B *
6" Long Solid Stainless Steel Electrode ONLY Recommend Converting to low maintenance WaveStart ®	87A285A *
6" Long Solid Stainless Steel Electrode Dome Complete Assembly Recommend Converting to low maintenance WaveStart®	87B309C *

<sup>\*</sup> Must identify correct electrode length requirement

<sup>\*\*</sup> If customer switches to 4L408Q, **Sonic Start™ or WaveStart®**, from the 4L29 Electrode Relay, the Rectifier/Diode, Resistor & Capacitor are no longer required in the control panel.



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 39

#### **VACUUM PRIMING SYSTEM (CONTINUED)**

### ELECTRODES - NEWER STYLE SOLID STAINLESS STEEL ELECTRODE \* FOR DOMES WITH ONE HOLE AT THE TOP (OLD TECHNOLOGY RELPLACED BY SONIC START® PROBE)

PART DESCRIPTION	PART #
51/4" Long Solid S.S. Electrode	87A285 *
6" Long Solid S.S. Electrode (used with PN 87A225 Dome Retrofit Adapter)	87A285A *
Jam Nut	6L222A
Small O-Ring (for top of dome)	11L4J
Large O-Ring (for base of dome)	11L4K
Male Quick Disconnect Fitting	1L460D
Ferrule Connection Fitting (OPTIONAL replacement for 1L460D)	1L248A
Female Reducer Coupling	1L552A
Reduced Maintenance Vacuum Priming System Retrofit Kit (Old PN: H87A310C)	OBSELETE

### **ELECTRODES – OLD STYLE:** FOR DOMES WITH TWO HOLES AT THE TOP, OLD TECHNOLOGY REPLACED BY SONIC START® PROBE.

PART DESCRIPTION	PART#
2-Hole Dome (old P/N 87B15 no longer available. Convert to <b>SONIC START® STREAMLINE™</b> with kit H87A391J)	OBSOLETE
Solid Aluminum Electrode (old P/N 87A72 no longer available. Convert to <b>SONIC START® STREAMLINE™</b> with kit H87A391F)	OBSOLETE
Gasket for Stud	87A31
Quad Ring (if surface of dome has a groove)	11L47D
Electrode Dome Gasket (if surface of dome is flat)	87A7
Stud for Electrode	6L51CF
Nut for 6L51CF (2 required)	6L60E
Bolt for Holder (2 required)	6L20CE
Flatwasher for Holder (2 required)	6L61F
Male Connector for Electrode Dome	1L248G
90° Connector for Tubing to Valves	1L190B
Straight Fitting for Tubing to Valves	1L248A
Insulator Boot	5L68B
Tubing, Green 3/8" (Other colors available – see page 47)	1L142BB



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 40

#### **VACUUM PRIMING SYSTEM (CONTINUED)**

ELECTRODES - OLDER STYLE HOLLOW ELECTRODE * FOR DOMES WITH ONE HOLE AT THE TOP (OLD TECHNOLOGY RELPLACED BY SONIC START® PR	
PART DESCRIPTION	PART#
5%" Long Hollow S.S. Electrode (Old P/N: 87B229A no longer available	
- Order 87B309C as replacement) (used with PN 87A225 Dome	OBSOLETE
Retrofit Adapter)	
5" Long Hollow S.S. Electrode (ONLY Available until current stock is depleted)	87A229B *
Bulkhead Union	1L481C
Terminal Lug	5L52G
Small O-Ring (2 required)	11L4J
Large O-Ring	11L4K
Retainer Ring (Compression Ring)	87A226
Retrofit Adapter Ring	87A225
Stud - Stainless Steel (2 required)	6L200DH
Nut - Stainless Steel (4 required)	6L30K
Washer – Stainless Steel (2 required)	6L65F
90° Elbow, 3/8" x 1/4"	1L190B
Quad Ring	11L47D
Insulator Boot	5L68B
Tubing, Green 3/8" (Other colors available – see page 47)	1L142BB
Ferrule, 3/8"	1L366C
Ferrule, Nut & Sleeve	1L786A
Electrode Dome Assembly Conversion Kit (Replaces H87B135 & H87A329)	
(converts 2 hole dome to 1 hole dome) Required when replacing the Old Style 87B15 Electrode Dome that has two holes at the top. (The kit Includes all parts in the 87B309C assembly and other parts needed for conversion.)	H87A329A
FLOAT CHECK VALVES – CURRENT STYLE	
PART DESCRIPTION	PART#
Float Check Valve, 3/8" NPT (Complete Assembly) (Replaces 1L443, 1L443G, and 87A76)	1L443H
Adapter Fitting, 3/8" x 1/4"	1L43D
Body (See drawing - not normally replaced)	
Ball Seat (for 1L443H)	1L443HA
Valve Ball 1½" Diameter	1L443B
O-Ring (for 1L443H)	1L443HB
Bowl Only (for 1L443H) (Also includes O-Ring P/N 1L443B)	1L443HC
Drain Valve	1L333
Float Check Valve <b>SONIC START® STREAMLINE™</b> Piping (connects between float check valve & vacuum tubing.) Includes gauge port, shut off valve & quick disconnect tubing connections	87B739



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 41

### VACUUM PRIMING SYSTEM (CONTINUED)

FLOAT CHECK VALVES – OLDER STYLE	
PART DESCRIPTION	PART#
Older Style Ball Seat (for 1L443G)	1L443A
Older Style O-Ring (around outside lip of 1L443)	1L443C
Older Style O-Ring (around inside lip of 1L443G)	1L443E
Older Style Bowl Assembly (for 1L443G)	1L443F
Drain valve (for 1L443 or 1L443G)	1L333
Older Style O-Ring (for 87A76)	1L410C
Older Style Bowl Assembly (for 87A76)	1L410D
Older Style Bowl Insert (for 87A76)	1L410H
QUICK DISCONNECT FITTINGS PART DESCRIPTION	
Quick Disconnect (new style) elbow – 3/8" x 1/4" NPT	1L546C
Quick Disconnect(new style) straight – 3/8" x ½" NPT	1L460D
Quick Disconnect(new style) straight & used on <b>SONIC START® STREAMLINE™ and WaveStart°</b> (P/N:87B728) Dome Assembly	1L460E
REDUCED MAINTENANCE VACUUM PRIMING SYSTE	EM KITS
PART DESCRIPTION	PART #
Reduced Maintenance Vacuum Priming System Retrofit	<b>5</b>
Kit (Includes one each 87B309B & 87B309C electrode	Replaced with <b>WaveStart</b> ®
dome assemblies, 4L408H electrode relay upgrade, 1L545A) (Obsolete P/N:H87A310C) Replacement part is <b>WAVESTART</b> ® P/N:H87391P	H87A391P
Electrode Dome Conversion/Reduced Maintenance Vacuum Priming Combo Kit (Includes H87A329A, 4L408H upgrade, and	Replaced with
1L545A solenoid upgrade) (Obsolete P/N:H87A330A) Replacement part is <b>WAVESTART</b> ® P/N:H87391P	<b>WaveStart</b> ® H87A391P
Vapor Filter 12-Pack Replacement Part Kit	H87A321A
· · · · · · · · · · · · · · · · · · ·	



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 42

#### **VALVES**

SOLENOID VALVES (IN PORT GOES TO DOME, OUT PORT GO	ES TO VACUUM PUMP)
PART DESCRIPTION	PART#
SONIC START® STREAMLINE™ and WaveStart® Vacuum Dome for Pump Stations (NEWEST Solenoid Dome Arrangement	87B728
2-Way Solenoid Valve (5/16" orifice) (Newest Solenoid – Upgrade from 1L406A & 1L406E Style)	1L545A remote mounted using standard DIN connection & used on SONIC START® STREAMLINE™ and WaveStart® Vacuur Dome
DIN Connector for 1L545A with 8' cord (OLD P/N: 1L545A-1) (Required for initial installation of 1L545A)	87A481-STK
Solenoid Clip (top piece removed when solenoid opened, clip holds unit in place)	1L545A-3
2-Way Solenoid Valve (5/16" orifice) (Newest Solenoid – Upgrade from 1L406A & 1L406E Style)	1L545B conduit connection mounted through panel & backpan
Solenoid Clip (top piece removed when solenoid opened, clip holds unit in place)	1L545A-3
Reduced Maintenance Vacuum Priming System Retrofit Kit USE H87A391J	OBSOLETE
2-Way Solenoid Valve (5/16" orifice) (Old PN: H87A343A) (Newest – Upgrade from 1L406A & 1L406E Style) USE H87A391J	OBSOLETE
3-Way Solenoid Valve (3/32" orifice) (Replaced Old Style 1L299A, 1L349A, 1L406A, & 1L406E) Current S&L standard solenoid valve is the PN 1L545A remote mounted needs DIN connector PN 1L545A-1 or PN1L545B that mounts through control panel and backpan. Conduit Connector, Ref: 87B16.)	1L406K
Conduit Nut for 3-Way Solenoid Valve (required when ordering 1L406E first time)	5L13A
Valve Sleeve Wrench for 1L406A	1L406W
Valve Sleeve Wrench for 1L406E	1L406EW
WAVESTART® KITS	
PART DESCRIPTION	PART#
WaveStart® Upgrade Kit for One Pump from SONIC START®	H87A391M
WaveStart® Upgrade Kit for Two Pumps from SONIC START®	H87A391N
WaveStart® Upgrade Kit for One Pump from Electrodes	H87A391P
WaveStart® TAP AND DRILL KIT	H87A390A



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 43

#### **VALVES**

PLUG VALVES	
PART DESCRIPTION	PART#
4" Plug Valve (requires 2 PN 11L1A flange gaskets)	2L104A-300 *
Handle/Wrench Only for 4" Plug Valve (Red)	2L104AA1
4" Flange Gasket	11L1A
6" 3-Way Tapered Plug Valve (requires 3 PN 11L1C flange gaskets)	2L148M-300 *
Handle/Wrench Only for 6" Plug Valve (Red)	2L104AA1
6" Flange Gasket	11L1C

PART DESCRIPTION	PART#
4" Left Hand Wafer Check Valve - requires (2) 11L1A, (4) 6L20HS & (4) 6L60L to install (replaces 2L139A, 2L161A, 2L153A, 2L153E)	2L153N*
4" Right Hand Wafer Check Valve - requires (2) 11L1A, (4) 6L20HS & (4) 6L60L to install (replaces 2L139B & 2L161B, 2L153B, 2L153F)	2L153P*
4" Flange Gasket (requires 2 per valve)	11L1A & 87A255
Bolt for 4" Valve Installation (4 needed per valve)	6L20HS
Nut for 4" Valve Installation (4 needed per valve)	6L60L
6" Left Hand Wafer Check Valve - requires (2) 11L1C, (4) 6L20JV & (4) 6L60M to install (replaces 2L139C & 2L161C, 2L153C, 2L153G)	2L153Q*
6" Right Hand Wafer Check Valve - requires (2) 11L1C, (4) 6L20JV & (4) 6L60M to install (replaces 2L139D & 2L161D, 2L153D, 2L153H)	2L153R*
6" Flange Gasket (requires 2 per valve)	11L1C & 87A244
Bolt for 6" Valve Installation (4 needed per valve)	6L20JV
Nut for 6" Valve Installation (4 needed per valve)	6L60M

<sup>\*</sup> NOTE: Arms and Shafts are now drilled for double roll pins.



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 44

#### **VALVES** (CONTINUED)

4L628N 4L628N
4L628N
4L628H
4L264
87A481-STk
5L49B
5L57L
5L150A
87A384
11L4J
6L222A
1L552A
1L460D
5L57L-2
5L57L-1
PART #
H87A391M
H87A391N
H87A391P

WaveStart® VACUUM DOME/SOLENOID VALVE ASSEMBLY

87B728



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 45

#### **VALVES** (CONTINUED)

#### SONIC START® VACUUM DOME INDIVIDUAL PARTS FOR P/N 87B452A

PART DESCRIPTION	PART #
Ferrule Connection Fitting (Optional)	1L248A
Male Quick Disconnect Connection Fitting, Brass	1L460D
Reducer Coupling, Brass	1L552A
Jam Nut, Brass	6L222A
Vacuum Dome Housing	87B133B
Small O-Ring	11L4J
SONIC START® Bulk Head Fitting, Brass	87A384
Large O-Ring	11L4K
VACUUM DOME	
PART DESCRIPTION	PART#
Vacuum Dome	87B133B
Little O-Ring (for top of dome)	11L4J
Large O-Ring (for bottom of dome)	11L4K

PART DESCRIPTION	PART#
Heavy Duty 1/6 HP (For Pumps with 4" Piping) (Complete pump)	8L29
Repair Kit (K264 or K265)	8L29AB
Inlet Filter	8L29A1
Head Gasket	8L29A4
Valve Outlet	8L29A5
Valve Plate	8L29A6
Inlet Valve	8L29A7
Cylinder Gasket	8L29A8
Piston Ring	8L29A10
Piston Seal	8L29A11
Rider Ring	8L29A12
Fan	8L29A20
Shroud	8L29A21
Motor, 1/6 HP 1725	Not Availab
Vibration Isolator (See Section 6)	87A291



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 46

VACUUM PUMP - STANDARD - SINGLE PISTON & SPARE PARTS		
PART DESCRIPTION	PART#	
Standard 1/8 HP (for pumps with 4" piping) (Complete pump)	8L44	
Piston Sleeve	8L44-5	

PART DESCRIPTION	PART#
Heavy Duty ½ HP (For Pumps with 6" Piping) (Complete pump)	
(replaces 8L40A*)	8L32**
Repair Kit (K262 or K263)	8L32-1
Head Gasket	8L32-2
Outlet Valve	8L32-3
Inlet Valve	8L32-4
Cylinder Gasket	8L32-5
Felt	8L32-6
Piston Ring	8L32-7
Piston Seal	8L32-8
Rider Ring	8L32-9
Valve Plate	8L32-10
Motor ½ HP 1725 RPM	Not Available
Shroud	8L32-12
Fan	8L32-13
Cylinder Head	8L32-14
Vibration Isolator (See Section 6)	87A291
,	

<sup>\*</sup> NOTE: Parts available for 8L40A – see drawing in Section 7

<sup>\*\*</sup> SEE SECTION 6 FOR COMBINED EXHAUST CONFIGURATION



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 47

OLD 8L40A VACUUM PUMP DUAL PISTON - SPARE PARTS ONLY		
PART DESCRIPTION	PART #	
Diaphragm	OBSOLETE	
Head (old P/N 8L40-9 no longer available)	OBSOLETE	
Fan Shroud	OBSOLETE	
Valve Keeper	8L40-14	
Diaphragm Hold Down Plate	OBSOLETE	
Head Screw	8L40-18- OBSOLETE	
Exhaust Flapper Screw	8L40-19- OBSOLETE	
Intake Flapper Screw	8L40-23- OBSOLETE	
Valve Plate Screw	8L40-24- OBSOLETE	
Filter Assembly	8L40-34- OBSOLETE	

\*Note: If complete pump is needed, replace with 8L32

VACUUM RELEASE VALVE		
PART DESCRIPTION		PART #
Vacuum Release Valve – Required for S0 STREAMLINE™ and WaveStart®. (Con H87A391P & H87A457 upgrade kit)		1L764B
VACUUM TUBING		
PART DESCRIPTION		PART #
=================================		
Vacuum Tubing - 3/8"	Natural:	1L142BA
	Natural: Green:	1L142BA 1L142BB



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 48

VACUUM TUBING FITTINGS (for electrode domes, solenoid valves, & float check valves)		
PART DESCRIPTION	PART#	
Ferrule (old style) elbow - 3/8" x 1/4" NPT	1L190B	
Ferrule (old style) straight - 3/8" x 1/4" NPT	1L248A	
Ferrule (old style - for 2-hole dome) straight - 3/8" x 1/8" NPT	1L248G	
Quick Disconnect (new style) elbow - 3/8" x 1/4" NPT	1L546C	
Quick Disconnect (new style) straight - 3/8" x 1/4" NPT	1L460D	
Quick Disconnect (new style) straight used on SONIC START® STREAMLINE™	1L460E	

VAPOR FILTER – NOT USED WITH SONIC ST WAVESTART®	ART <sup>®</sup> STREAMLINE™OR
PART DESCRIPTION	PART#
Vapor Filter 12-Pack Replacement Part Kit	H87A321A

<sup>\*</sup> NOTE: Arms and Shafts are now drilled for double roll pins.



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 49

### **VACUUM PRIMING SYSTEM (CONTINUED)**

4" Wafer Check Valve Spare Part	s		'
PART DESCRIPTION	2L153A,B PART #	2L153E,F PART #	2L153N,P (-300) PART #
Seat Ring	55A30	55A38C ***	11L207F
Brass Arm *	Obsolete **	Obsolete **	55A32
Brass Clapper	55B39	55B39	55B39
Shoulder Bolt - Stainless Steel	6L184A	6L184A	6L184A
Roll Pin - Stainless Steel	2L153A6	2L153A6	2L153A6
Shaft - Stainless Steel *	55B44	55B44	55B32
Bronze Bushing (2 required)	55A34	55A34	55A34
O-Ring (2 required)	2L153A9	2L153A9	2L153A9
Steel Bar Arm/Handle	Obsolete **	55A36	55A36
Pin - Stainless Steel	2L153A11	2L153D11	2L153D11
Eye Bolt (from body to spring)	6L55N	6L55N	6L55N
Spring - Stainless Steel	11L104N	11L104N	11L104N
Pipe Plug	1L69B	1L69B	1L69C
Eye Bolt (from handle to spring)	6L55M	6L55M	6L55M
4" Flange Gasket (2 required per valve)	111L1A or 87A255	111L1A or 87A255	11L1A or 87a255

<sup>\*</sup> NOTE: Arms and Shafts are now drilled for double roll pins. \*\* Not Available – must order new check valve

<sup>\*\*\*</sup> Cut to size, then use Permatex Black Max 380 or Loctite Blue to connect ends & to glue O-Ring to Seat.



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 50

#### **VALVES** (CONTINUED)

6" Wafer Check Valve Spare Part	S		
PART DESCRIPTION	2L153C,D PART #	2L153G,H,L,M PART#	2L153Q,R (-300) PART #
Seat Ring	55A31	55A38D ***	11L207G
Brass Arm *	55A33	55A33	55A39
Brass Clapper	55B29/55B40	55B2955B40	55B40
Shoulder Bolt – Stainless Steel	6L184B	6L184B	6L184B
Roll Pin - Stainless Steel	2L153C6	2L153C-12	2L153C-12
Shaft - Stainless Steel *	Obsolete **	Obsolete **	55B37
Bronze Bushing (2 required)	55A35	55A35	55A35
O-Ring (2 required)	2L153C9	2L153C9	2L153C9
Steel Bar Arm/Handle	55B31	55A37	55A37
Pin - Stainless Steel	2L153C11	2L153A11	2L153A11
Eye Bolt (from body to spring)	6L55N	6L55N	6L55N
Spring - Stainless Steel	11L104N	11L104M	11L104M
Pipe Plug	1L69B	1L69B	1L69D
Eye Bolt (from handle to spring)	6L55M	6L55M	6L55M
6" Flange Gasket (2 required per valve)	11L1C or 87A224	11L1C or 87A224	11L1C or 87A224
•			

<sup>\*</sup> NOTE: Arms and Shafts are now drilled for double roll pins. \*\* Not Available – must order new check valve

\*\*\* Cut to size, then use Permatex Black Max 380 or Loctite Blue to connect ends



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 51

#### **SUGGESTED SPARE PARTS**

FOF SUGGESTED SPARE PARTS PART DESCRIPTION	PART#
Mechanical Seal (Select the correct seal for your pump)	IANI#
( ) B-Shaft Single Mechanical Seal – 1-7/8"	H87A28
( ) C-Shaft Single Mechanical Seal – 1-7/8"	H87A97
( ) D-Shaft Single Mechanical Seal – 2"	H87A534
Volute Gasket (Select the correct volute gasket for your pump) A new volute gaster the rotating assembly (motor, impeller, mechanical seals, and /or volute) is disassembled.	
( ) 4B2B, TURBO 4B2C, 4B2C, 4C2B, 4C2D	60A26 (1/ <sub>32</sub> ")
( ) 4B3B, 4C3B, 4D3B, 6B3B (& SERIES), 6C3B (& SERIES), 6D3B (& SERIES)	60A28 (1/ <sub>32</sub> ")
( ) 4D4B	60A106B (1/ <sub>32</sub> "
( ) 8C4D, 8D4D	60A106B (1/ <sub>32</sub> "
Seal Housing Gasket (Select the correct gaskets for your pump) A new seal he each time the mechanical seal is replaced.	ousing gasket is requir
( ) Flat – B-Shaft – 1-7/8" – Older Style	60A11
( ) Flat – C-Shaft – 2-1/8" – Older Style	60A17
( ) Flat – D-Shaft – 3" – Older Style	60A84
( ) Quad Ring – B-Shaft – 1-7/8" – Seal Housing with Groove	60A110
( ) Quad Ring – C-Shaft – 2-1/8" – Seal Housing with Groove	60A111
( ) Quad Ring – D-Shaft – 3" – Seal Housing with Groove	60A146
<b>Nylock Impeller Bolt</b> (Select the correct bolt for your pump) A new Nylock Imperfrom a safety standpoint each time it is removed.	ller Bolt is recommend
( ) B-Shaft & C-Shaft Nylock Impeller Bolt – 1-7/8" & 2-1/8"	60A12
( ) D-Shaft Nylock Impeller Bolt – 3"	60A87
Impeller Washer (Select the correct washer for your pump)	
( ) B-Shaft & C-Shaft Impeller Washer – 1-7/8" & 2-1/8"	60A20
( ) D-Shaft Impeller Washer – 3"	60A86
Prime Sensing Probe (Select the style installed on your pump station)	
( ) 5-1/4" Long Solid S.S. Electrode Dome Assembly	87B309B
( ) 6" Long Solid S.S. Electrode Dome Assembly	87B309C
( ) SONIC START® Prime Sensing Probe	4L628N
Vacuum Dome Small O-Ring (P/N 11L4J) & Large O-Ring (11L4K) are recommended (not included with dome).	87B133B
Vacuum Tubing – 3/8" - Red	1L142BC



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 52

#### **GENERAL LIST OF OTHER POSSIBLE SPARE PARTS**

PART DESCRIPTION	PART #
Alternator (Select the correct alternator for your pump)	
( ) Alternator – New Style 2-Pump P.S. (plug-in with 11 pin)	4L187B
( ) Socket Base, 11 pin, for Alternator 4L187B	5L49C
( ) Alternator – Old Style 2-Pump P.S. (replaces 4L187, 12 Pin)	4L187A
( ) Socket Base, 12 pin, for Alternator 4L187A	5L161
( ) Alternator/Timer for old stations, 2 Switches, Wire-In 16 Hour (8 on/off) Replaces Zenith 4L282A	4L343
Customer will require wiring installation instructions if this replaces a PN 4L282A  ( ) Alternator/Timer for new stations, 1 Switch, Wire-In 16 hour (8 on/off)	4L365A
( ) Relay, Alternator	4L105A
Blower (Select the correct blower for your pump station)	
( ) Blower – 265 CFM (Newer Stations)	7L195
( ) Blower – 110 CFM (Older Stations)	7L40
CR Relay (Vacuum Pump Relay) (Select the correct CR Relay for your station)	
( ) Relay for Vacuum Pump (1CR, 2CR)	4L107F
( ) Relay for Vacuum Pump (1CR, 2CR) "Series Stations"	4L424A
ER Relay (Electrode Relay) (Determine which ER Relay or SONIC START® STREAMLINE™ is installed on pump station)	
( ) Electrode Relay (most current ER relay)	4L408Q
( ) Electrode Relay (oldest style)	4L29
( ) Rectifier/Diode, Resistor, Capacitor (required only if 4L29 Electrode Relay is installed)	80A145
Float Check Valve	1L443H
SONIC START® STREAMLINE™ OPERATING MODULE	4L264
WAVESTART® OPERATING MODULE	4L264E
Float Check Valve Drain Valve	1L333
Float Switches (Determine which floats are installed on your pump station)	
( ) Normally Open Float Switch (typical)	4L291A
( ) Normally Closed Float Switch (Special Alarms only)	4L291B
H-O-A Toggle Switch (3 Position), SPST (Not UL Listed) (replaces 4L207A)	4L272A
Impeller (Must be identified by pump station serial number)	Call Factory
Off-On Test Selector Switch, Toggle Switch, SPST (Not UL Listed)	4L23A



14040 Santa Fe Trail Lenexa, KS 66215-1234, USA After Market
Parts Price Book
Section 4
Recessed WWMPS
Parts
3/1/21 Page 53

#### GENERAL LIST OF OTHER POSSIBLE SPARE PARTS (CONTINUED)

PART DESCRIPTION	·	PART #
Paint (Determine which paint your station requires)		
* Order one gallon of Catalyst Part B for each gallon of pair	nt/primer – must be mixe	ed before use.
( ) Dark S&L Green <b>VERSAPOX</b> ®, Part A, Gallon		12L104B *
( ) Light Green <b>VERSAPOX</b> ®, Part A, Gallon		12L109B *
( ) Aquamarine <b>VERSAPOX</b> ®, Part A, Gallon		12L181B *
( ) VERSAPOX® Catalyst, Part B, Gallon		12L105B
( ) Primer (RED), Part A, Gallon		12L138A *
( ) Primer Catalyst, Part B, Gallon		12L138B
( ) Touch-Up Paint Kit – Aquamarine		H87A424
( ) Touch-Up Paint Kit – Light Green		H87A426
( ) Touch-Up Paint Kit – Georgian Hemlock		H87A425
Solenoid Valve (Select the style installed on your pump sta	ation)	
()3-Way Solenoid Valve		1L406E
( ) 2-Way Solenoid Valve (Remote Mounted using statement connection and used on SONIC START® STREAMLING WaveStart® Vacuum Dome)		1L545A
( ) 2-Way Solenoid Valve (Conduit connection Mount Backpan)	ed Through Panel &	1L545B
Temperature Control, 37º to 52º Heater		4L135B
Temperature Control, 90° to 75° Blower		4L135C
Thermostat Switch for Heater		OBSOLETE
Tubing (Select the correct tubing for your pump station)		
()Vacuum Tubing – 3/8"	Natural:	1L142BA
	Green:	1L142BB
	Red:	1L142BC
()Vacuum Tubing – 1/4"	Red:	1L142AC
()Vacuum Tubing - 1/2"	Natural	1L142CA
Vacuum Pump (Select the correct vacuum pump for your s	station)	
( ) Heavy Duty 1/6 hp Single Piston Vacuum Pump		8L29
( ) Standard Duty 1/8 hp Single Piston Vacuum Pump	)	8L44
( ) Heavy Duty 1/2 hp Dual Piston Vacuum Pump		8L32
Valves – Check Valve, Spring Loaded		Call Factory
Valves – Plug Valve		Call Factory
Vapor Filter – 12-Pack Replacement Kit		H87A321A